

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45976	04A0455	J.R.D. Electric Corp. 67-11 79th Street Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	75 Rockefeller Plaza New York NY	Approved	\$650.00
45977	04A0456	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	2100 Bartow Avenue Bronx NY	Ok, but	\$650.00
1) Show 3rd fuse-1st & 2nd fuse same rating. 2) Correct voltage in short circuit note.						
45978	04A0457	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	50 Sutton Place South New York NY	Approved	\$650.00
45979	04A0458	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	St. Vincent's Hospital 153 West 11th Street New York NY	Ok, but	\$650.00
Provide info on ATS's						
45980	04A0459	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	38 Greene Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45981	04A0460	Daniel Borriello Electric Inc. 1468 86th Street Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	2166 Coney Island Avenue Brooklyn NY	Ok, but	\$650.00
Show more detail of service switch #6, 2500A feeder-size? New tap?						
45982	04A0461	Judd Electric, Inc. 1097 Second Avenue, Suite 300 New York NY 10022	Requested approval for the electric service equipment proposed to be installed	180 Varick Street New York NY	Approved	\$650.00
45983	04A0462	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	902 Broadway New York NY	Approved	\$650.00
45984	04A0463	Al,s Best Electric Co., Inc. 915 Broadway, Suite 607 New York NY 10003	Requested approval for the electric service equipment proposed to be installed	380 Second Avenue New York NY	Approved	\$650.00
45986	04A0464	Vista Electrical Contractors, Inc. 2377 Washington Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	Jewish Home and Hospital 100 West Kingsbridge Road Bronx NY	Hold	\$650.00
Not Reviewed. Plans are rolled up not Advisory Board format. Engineer to appear at next meeting.						

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45987	04A0465	Lippolis Electric, Inc. 445 Fifth Avenue Pelham NY 10803	Requested approval for the electric service equipment proposed to be installed	Jacob Nursing Home 1160 Teller Avenue Bronx NY	Approved	\$650.00
1) 1200A feeders undersized. 2) Provide Cutler-Hammer drawings of equipment. 3) ATS's-4 pole on 4 wire loads. 4) Location of new service switch obstructs rear egress. 5) Indicate bus sizing per Article 408 (not 1000A/Sq. in).						
45988	04A0466	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Commerce Bank 155 Canal Street New York NY	Approved	\$650.00
Increase service bus to 3x 1/4 x 6".						
45989	04A0467	Stonehill Electric Corp. 33-00 Northern Blvd.-Lobby Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	15 West 37th Street New York NY	Approved	\$650.00
45990	04A0468	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	85 10th Avenue New York NY	Approved	\$650.00
45991	04A0469	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Bank of America 800 Avenue of the Americas New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45992	04A0470	Associated Electrical Contrs of N.Y. Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	629 West 54th Street New York NY	Approved	\$650.00
45993	04A0471	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	780 8th Avenue New York NY	Approved	\$650.00
45994	04A0472	AC Electrical Services, Inc. 142 West 19th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	20-22 Mercer Street New York NY	Hold	\$650.00
45995	04A0473	Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	257 Park Avenue South New York NY	Approved	\$650.00
45996	04A0501	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1156 6th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45997	04A0474	High-Rise Electric, Inc. 13-15 Jackson Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	25 West Houston Street New York NY	Approved	\$650.00
45998	04A0475	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Columbia Residence 2700 Broadway New York NY	Approved	\$650.00
Check 2500A to 1600A.						
45999	04A0476	Barth-Gross Electric Co., Inc. 110 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Empire State Building 350 Fifth Avenue New York NY	Approved	\$650.00
46000	04A0477	Kings Electric Company, Inc. 2113 West 6th Street Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	195 Bowery Street New York NY	Approved	\$650.00
46001	04A0478	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	AT & T Site #839 86-25 Van Wyck Expressway Jamaica NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46002	04A0479	Stability Electrical Enterprises, Inc. 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	AT & T Site #870 65 Oriental Boulevard Brooklyn NY	Approved	\$650.00
46003	04A0480	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Palace 455 Madison Avenue New York NY	Approved	\$650.00
With the stipulation the stipulation that the 1)Automatic transfer switch does not feed life safety equipment. 2)The overlapping neutral is not an option.						
46004	04A0481	Switch Contracting, Inc. 178 Industrial Loop, Bay 2 Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Pennmark 315 West 33rd Street New York NY	Approved	\$650.00
46005	04A0482	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens Center Mall 90-15 Queens Blvd. Queens NY	Approved	\$650.00
46006	04A0483	BLZ Electric, Inc. 620 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	169 Hudson Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46007	04A0484	Amber Lite Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Schaefer Development 444 Kent Avenue (South Tower) Brooklyn NY	Approved	\$650.00
46008	04A0485	Amber Lite Electric Corp. 4830 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Schaefer Development 450 Kent Avenue (East Tower) Brooklyn NY	Approved	\$650.00
46009	04A0486	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Hospital 48th Street & Tenth Avenue Brooklyn NY	Approved	\$650.00
46010	04A0487	Rothstein & Hoffman Electric 255 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Gen Kin Plaza 37-02 Main Street Flushing NY	Ok, but	\$650.00
1) Increase size of conductors off of service switch #5. 2) Change 600 amp CT to 800 amp.						
46011	04A0488	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The W Court Hotel 130 East 39th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46012	04A0489	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	1 NY Plaza New York NY	Approved	\$650.00
46013	04A0490	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 3 Metrotech Center Brooklyn NY	Approved	\$650.00
<p>1) Provide details of cable connections between generator main circuit breaker and paralleling switchgear (routing, wiring method, etc) show where outdoor. 2) Provide short circuit and coordination study. 3) Provide floor plan of generator enclosure.</p>						
46014	04A0491	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	250 W. 57th Street New York NY	Approved	\$650.00
46015	04A0492	Forest Electric Corp. 111 8th Avenue New York NY 10011	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00
<p>Service bus ties to be 4-1/4"x6" cu.</p>						
46016	04A0493	King Electrical Services, Inc. 2420 Hoffman Street Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	245 Park Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46017	04A0494	DiFazio Electric NY, Inc. 100 Milden Avenue Staten Island NY 10301	Requested approval for the electric service equipment proposed to be installed	St. John's University Gym Building Queens NY	Approved	\$650.00
46018	04A0495	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	350 W. 53rd Street New York NY	Approved	\$650.00
46019	04A0496	Daniel Borriello Electric Inc. 1468 86th Street Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	Yeshiva Ateret Torah 2166 Coney Island Avenue Brooklyn NY	Void	\$650.00
1) Confirm availability of 600 KCM cable terminations at Con-Ed property line box. 2) Correct notes-indicate bus sizing per Article 408.						
46020	04A0497	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	731 Flushing Avenue Brooklyn NY	Approved	\$650.00
46021	04A0498	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	17-19 West 34th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46022	04A0499	Associated Electrical Contrs of NY Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	10 Waterside Plaza New York NY	Approved	\$650.00
46023	04A0500	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Hines-Deutsche Bank 31 West 52nd Street New York NY	Approved	\$650.00
46024	04A0502	Ryan Electric Company, LLC 65 West 55th Street, Suite 301A New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Riverdale Country School 5250 Fieldston Road Bronx NY	Approved	\$650.00
46025	04A0503	Sure Electrical Contracting Corp. 3836 Richmond Avenue Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	25 Hudson Street New York NY	Approved	\$650.00
Indicate P.O.E. on floor plan.						
46026	04A0504	CMS Electrical Service Co., Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	787 7th Avenue New York NY	Approved	\$650.00
Provide floor plan of generator room.						

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46027	--	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requesting permission on previously approved equipment submittal (Cal. # 45975, ceiling level lighting and power distribution system. Model USL-E230973 by Herman Miller, Inc.) to include the smart connector with three wire enclosure to feed more than one fixture. As per the Advisory Board approval stipulation.	Citywide	Approved	\$0.00
The three wire enclosure can feed more than one fixture as per New York City's amendment 604.1(A)4. All branch circuits are limited to a maximum of ten outlets per circuit, 15 or 20 amp branch circuits shall not exceed 80% of their ratings. All installations must fully comply with Article 604 of New York City's amendments.						
46028	..	Alt Power Inc. 160 Fifth 160 Fifth Avenue, Suite 807 New York NY 10010	Requesting permission to allow the installation of custom laminated photovoltaic (PV) modules that are not listed by a nationally recognized testing laboratory but are built to UL 1703 standard.	The Helena 601 West 57th Street New York NY	Hold	\$0.00
1)Need more details of the wiring methods that will be used. 2) Is this system running parallel with Con-Edison. 3) Must be submitted as a complete system. 4) What is the DC operating voltage.						
46029	...	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requesting permission not to file Advisory Board Drawings to replace defective sections of two bus ducts with conduit and wire and installing two new cable tap boxes to pick up the bus ducts on a service over 1000 KVA.	Newmark Real Estate 17 Battery Place New York NY	Approved	\$0.00
One time, one location only.						
46030	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission in a building that has multiple services to install a grounding copper detail collector bus that will pick up all the neutrals from the service switches, grounding electrode conductors from building steel and line side of water main on a job over 1000 KVA.	Queens Center Mall 90-15 Queens Blvd. Elmhurst NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46031	---	425 Park Avenue Company 425 Park Avenue New York NY 10022	Requesting permission to reutilize existing electrical closets without mandated clearances that contain electrical equipment and replacement low voltage telephone cables for temporary power and telephone service inside a building that had a major electrical fire.	425 Park Avenue New York NY	Approved	\$0.00
<p>With the stipulation that special permission is not required for temporary wiring. The installation shall conform to Article 527 of the 2002 National Electrical Code and local amendments. Electrical permits must be filed by the licensed contractor performing the work and the contractors are responsible for the work until the temporary wiring is removed and a final certificate is issued. The Board recommends that the in a sheetrock enclosure be replaced as soon as possible.</p>						
46032	----	Pratt Planning and Archit,l Collaborative 379 DeKalb Avenue Brooklyn NY 11205	Requesting permission to use lifeline RHH 2 hour fire rated conductors installed in conduit without concrete encasement to extend service entrance conductors inside a building.	Cooper Square Supportive 29 E. 2nd Street New York NY	Denied	\$0.00
<p>Section 230.6 of the National Electrical Code requires the conduits to be installed beneath the building under not less than 2 inches of concrete or concealed in a raceway within the building and encased by not less than 2 inches of concrete or brick or installed under 18 inches of earth beneath the building to extend service entrance conductors within a building.</p>						
46033	----	Jaros Baum & Bolles Consulting Engs 80 Pine Street New York NY 10005	Requesting permission to install a 460 volt disconnect switch inside of an electrical closet with a front clearance of 36 inches facing existing panels.	AXA Insurance 17 State Street-36, 37th Floor New York NY	Approved	\$0.00
46034	-----	AA Reale Electric Inc. 4223 1st Avenue Brooklyn NY 11232	Requesting permission to leave as installed due to lack of space inside the service room a new 400 amp circuit breaker panel mounted on a wall next to the switchgear where one quarter of the front of the panel has a front clearance of 30 inches to the side of the switchgear.	1133 Broadway New York Ny	Approved	\$0.00
<p>As per Advisory Board drawing, Calendar #43030.</p>						

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46035	-----	Richard Jensen Electric, Inc. 34-02 Review Avenue Long Island City NY 11101	Requesting permission to leave as installed a 1200 amp service switch fed by 3-sets of 500 MCM with 1000 amp fuses due to the hardship of adding another set of conductors.	33-30 57th Street Queens NY	Approved	\$0.00
With the stipulation that signage is affixed to the 1200 amp switch indicating that the fusing shall not exceed 1000 amps.						
46036	-----	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requesting permission to install service equipment that will be facing each other with a front clearance of 54 inches on a 1000 KVA service that will be submitted to the Advisory Board in the future.	82-50 164th Street Jamaica NY	Denied	\$0.00
As per the electrical Advisory Board rules, See Section 230.64(B)(1) at least seven feet of clearance is needed in front of the switchboards when they are installed facing each other.						
46037	-----	Platinum Electrical Contracting Inc. 360 Industrial Loop Road Staten Island NY 10309	Requesting permission to leave as installed service equipment for four stores located on the outside of the building inside a structure attached to the building with double doors.	Strip Mall 4906 Arthur Kill Road Staten Island NY	Approved	\$0.00
Section 230.70(A) of New York City's amendments prohibits the installation of service equipment on the outside of a building with the exception of residential buildings of one through four dwellings units. Your request to install the service equipment inside of an attached room with a roof and two floor to ceiling double doors is approved with the stipulation that electrical equipment is listed and approved for outdoor use.						
46038	**	Commercial Electrical Contractors, Inc. 10-28 47th Avenue Long Island City NY 11101	Requesting permission to install PVC Schedule 40 conduit underground encased in concrete for service entrance conductors.	89-35 162nd Street Queens NY	Approved	\$0.00
46039	-----	DiRusso Electrical Contracting 63-23 Metropolitan Avenue Middle Village NY 11379	Request permission due to the water main being located 500 feet away from the service equipment to install ground rods in lieu of the street side of the water main.	88-08 83rd Avenue Queens NY	Approved	\$0.00
With the stipulation that in addition to the installation of the two ground rods, cold water and building steel shall be bonded.						

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46040	***	Polaris Electrical Construction Inc. 738 New Lots Avenue Brooklyn NY 11207	Requesting permission to retro-fit existing feed through fuse boxes with Cutler-Hammer components.	83-75 and 83-77 Woodhaven Blvd. Woodhaven NY	Approved	\$0.00
With the stipulation that the feeder neutrals are spliced together prior to being terminated on the neutral block.						
46041	****	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission one time one location to install a custom non-listed lighting fixture made of approved listed components.	Bloomberg 731 Lexington Avenue New York NY	Denied	\$0.00
No ground, no complete submittal.						
46042	04A0505	Permasteelisa Cladding Technologies, Ltd. 123 Day Hill Rd. Windsor CT 06095	Requested approval for use in New York City of your Conduit. Model/Series No. PAST-10B.		Approved	\$200.00
Flexible non metallic conduit is permitted in New York City as per Article						
46043	04A0506	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Ceiling Level Lighting and Power Distribution System. Model/Series No. USL-E230973 components 277/120 volt Relay/Dimmer Module 1B11Y4.		Hold	\$200.00
Waiting for UL report and sample of the junction box.						
46044	04A0507	X-Tra Light LLC 8812 Frey Rd. Houston NY 77034	Requested approval for use in New York City of your. Fluorescent Light. Model/Series No. EHB-454.		Approved	\$200.00

ADVISORY BOARD CALENDAR

November 17, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46045	04A0508	Milbank Manufacturing Company 4801 Deramus Kansas City MO 64120	Requested approval for use in New York City of your Meter Socket. Model/Series No. U3532.		Hold	\$200.00
Lug size must be stipulated by the manufacturer to avoid the possibility of the wrong lug being used.						
46046	04A0509	Encore Lighting LLC 57-10 49th Place Maspeth NY 11378	Requested approval for use in New York City of your Exit & Emergency Lighting. Model/Series Nos. 6EB/12EB/Endurance/LSE/LC8 Series.		Hold	\$200.00
Pending verification that endurance series housing complies with the thickness requirements of NYC 410.40.						
46047	*	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission due to the long distance location of the water main valves to bond the multiple service switches to ground by installing a bonding jumper from the street side of the water main valve to the building steel and bond the neutrals of the service switches to the steel in each cluster of buildings that has a Con-Ed point of entrance on a job filed under the old New York City Electrical Code.	Parkchester N. Apartments North Cluster Bronx NY	Approved	\$0.00
With the stipulation that the building steel establishes a ground-fault current path to ground and complies with Article 250.56 of the NEC.						