

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53319	15A0349	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	124-02 Roosevelt Avenue Flushing NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53418	15A0386CO2	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	7 West 21st Street New York NY	Approved	\$0.00
Carry over from 8/12/15 meeting. Service board "A" section bus undersized in cubicle next to 2500 amp s.s. calculations. 1/7/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53604	15A0564	JW Electric Corp. 1106 East 43rd Street Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	475 Locke Street Brooklyn NY	Approved	\$650.00
1) Provide documents to verify that PP-RT-1 is series rated. 2) DP-MB, verify metering. 3/1716 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11//28/16 Swapped drawings 1 and 2 of 3-Revision 2. 1/31/17 swap dwg 1,2 & 4 rev 3						
53959	15A0599	Allan Briteway Electrical Contractors, Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Trinity School 114 West 92nd Street New York NY	Approved	\$650.00
<p>1) SS #2-600 TR and emergency side 600 AZD does not coordinate with downstream TR fuses. 2) SS #4 does not coordinate with 600 amp AZD. 3) Clarify that ATS B-LS-WB feeds fire alarm system. 4) Provide coordination study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/30/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53612	15A0621	C.M. Richey Electrical Contractors, Inc. 347 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	540 West 26th Street New York NY	Approved	\$650.00

1) Time Warner power supply service to be bonded and grounded, why are there 2 switches. 2) Bond neutral to the end box, PVC conduits being used. 3) Show conductors and wiring method to load banks. 4) Add note on drawing indicating whether generator is a separately derived system or not with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label nor to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/17/16 Load bank feeders overfused. Error. 3/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements

53333	15A0626	azen and Sawyer Environ. Engs & Scientists 498 Seventh Avenue, 11th Floor New York NY 10018	Requesting permission to connect the grounding electrode conductors for the fire alarm service switch to the buildings grounding grid collector bus system in lieu of installing a dedicated grounding electrode conductor from the fire alarm service switch to the water main	Manhattan Pumping Station 184 Avenue D New York NY	Approved	\$350.00
-------	---------	---	---	--	----------	----------

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

15A0627	azen and Sawyer Environ. Engs & Scientists 498 Seventh Avenue, 11th Floor New York NY 10018	Requesting permission in a building that has six multiple sources of utility supplies, two sources of emergency generator supply, and a 30 KVA UPS system, to allow the fire alarm system supply to be fed from multiple ATS' that are fed from these multiple sources	Manhattan Pumping Station 184 Avenue D New York NY	Denied	\$350.00
---------	---	--	--	--------	----------

Installation is not code compliant.

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0633	Egg Electric Inc. 35 West 45th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	726 Broadway New York NY	On Hold	\$650.00
<p>1) Provide generator room layout. 2) Fire pump emergency feeder to be fire rated. 3) Verify that emergency side of fire pump does not share section with non-emergency loads. 4) Fire pump grid is under sized. 5) Verify F.P. circuit is fire rated to fire pump ATS. 6) Address coordination study issues and provide T.C.C. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53316	15A0639	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	114 West 47th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53318	15A0640	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1133 Sixth Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53510	15A0650	Scott Electrical Service, LLC 40 Macon Street Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Brighton Towers 40 Brighton 1st Road Brooklyn NY	Approved	\$650.00
<p>1) Through bus to last section to service switch 2 and 3 undersized. 2) Show feeders and wiring methods to existing panel boards. 3) Show fuse types in panel boards. 4) SS# 3 does not coordinate with 225 amp TR's with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/11/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/6/17 Swapped drawings A and B-Revision 2</p>						
53543	15A0653	Allcom Electric Corp. 243 East 138th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	600 West 58th Street New York NY	Approved	\$650.00
<p>1) Show lengths of transformer secondary taps. 2) MS.S. to have GFI. 3) Gen remote switch to have GFI. 2/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	15A0659	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	1711 First Avenue New York NY	Denied	\$650.00
<p>1) Fire pump incorrect amperage of conductors noted on 40 HP F.P. 2) Provide letter from Con-Ed stating incoming fault current. 3) Manufacturer's cut sheets of equipment not provided. 4) Coordination study to be provided by a P.E. and stamped. 5) Review stopped.</p>						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53426	15A0670	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Brooklyn Health Center 620 Fulton Street Brooklyn NY	Approved	\$650.00
<p>1) Verify that transformer and their disconnect switches comply with 110.26(A)(3) in the service room. 2) 1 Line doesn't match physical in 4000 amp ss section TVSS and 30 amp pullout, same in 3000 amp section. 3) Service entrance conductors undersized to C.T. 4) Is this an Article 517 installation? with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/11/16 Job finalized This drawings with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53346	15A0675	Light Corporation 14800 172nd Avenue Grand Haven MI 49417	Requested approval for use in New York City of your LED Under Cabinet Luminaire. Model/Series numbers: Clique/Clique.12; Clique.22; Clique 32; Clique.42.		Approved	\$200.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53947	15A0688	Kleinberg Electric Inc. 174 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	300 Jay Street Brooklyn NY	Approved	\$650.00
<p>1) Elevator #8 overfused. 2) Short circuit study not provided. 3) Elevator load calculations not provided. 2/18/16 Rejected Short circuit study not provided. 6/28/16 Job finalized.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0691	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Federal Reserve Bank of NY 33 Maiden Lane New York NY	Denied	\$650.00
1) Fuse types not shown on drawing. 2) No bonding and grounding of existing service switch.						
53544	15A0707	Roz-A-Lite Electrical Contracting Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	170 Amsterdam Avenue New York NY	Approved	\$650.00
<p>1) Show length of transformer secondary tap to VL-B switch, and lengths of other transformer secondary conductors. 2) Show size of FA transformer and type of ATS. 3) 1200 amp transformer disconnect switch fuse does not coordinate with 800 amp fuse. 4) Load side of generator though, show tap method and wire sizes to disconnect switches with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/19/16 Job finalized. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/20/16 Swapped drawing D1 & D2-Revision 2.</p>						
53473	15A0709	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	300 Park Avenue South New York NY	Approved	\$650.00
1) 4000A fuse type not shown on drawing. 2) Show elevation drawing of steam pipes with deflection shield, show how bus duct will pass over or under steam pipes. 3) Relocate LPB panel to comply with 110.26(E). 1/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0710	Sure Power Electric Inc. 246-10 Francis Lewis Blvd. Queens NY 11422	Requested approval for the electric service equipment proposed to be installed	Watchtower #2 73 Sands Street Brooklyn NY	On Hold	\$650.00
<p>1) Verify the amount of grounding electrode conductors, explain 3/0 GEC on service switches locks like neutral bonds. 2) Show fuse types in 400 amp Trans-s, if not supplying fuses say by others on drawing. 3) Show transition boxes for Vitolink cable in generator room. 4) Verify neutral bonds in remote service switches. 5) Verify whether gen set is separately derviced or not. 6) Coordination study not provided. 7) Gen set cut sheet is for the generator only not switchboard. 8) Provide complete submittal with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53550	15A0712	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	3 Chase Metrotech Center Brooklyn NY	Approved	\$650.00
<p>1) 1 Line doesn't match physical or manufacturer's cut sheet. 2) Is switchgear rear accessible? 3) Is all work in UPS room new, bubble new work. 4) Indicate interlock on the CB. 5) Verify poles of ATS, 3 wire system. 2/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53328	15A0713	Right Away Electric LLC 56-12 Andrews Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	525 Clinton Avenue Brooklyn NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53522	15A0715	FSM Electrical Corporation, Inc. 36-08 9th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	636 Louisiana Avenue Brooklyn NY	Approved	\$650.00
<p>1) Where is the Con Edison box located, verify 15 sets of service entrance conductors. 2) Show fuse types on 1 Line drawing. 3) Show withstand rating of the fire pump controller. 4) Show how generator will be protected for faults downstream of the 1200 amp circuit breaker. 5) Coordination study to be signed and sealed by PE with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/17/16 Job finalized..Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53327	15A0716	Martin Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	4315 16th Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53334	15A0717	Citywide Electrical Contractors Inc. 49 Bartlett Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	10 Lexington Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/18/16 Swapped drawing 1-Revision 1. 8/30/16 Swapped drawing 1-Revision 2.						
53335	15A0718	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	1515 Broadway New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53800	15A0719	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	1180 6th Avenue New York NY	Approved	\$650.00
Signage to be placed at the doors. 1/27/16 Rejected. Drawing to light to be read. 5/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53355	15A0722	ECNY Electric 42 West 38th Street, Suite #501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	X380-John Wayne Elementary 370 Marcy Avenue Brooklyn NY	Approved	\$650.00
OR 1) Who will be performing bus installation modifications to add the service switch to the Con-Edison service end box? 2) Installation to comply with 690.17. 12/3/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 ER Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 OK, with the stipulation that: JAP6 72/295-315/3BB modules, Advanced Energy AE 3TL 1000 series 3 phase transformerless string inverters, conext CL-NA 3 phase grid tie inverters, 1000 volt equipment can be installed.						
53353	15A0723	ECNY Electric 42 West 38th Street, Suite #501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	K278-Marine Park School 1925 Stuart Street Brooklyn NN	Approved	\$650.00
OR 1) Verify compliance with Section 690.64(B)(2) and 690.64(B)(4). 12/3/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 ER Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 OK, with the stipulation that: JAP6 72/295-315/3BB modules, Advanced Energy AE 3TL 1000 series 3 phase transformerless string inverters, conext CL-NA 3 phase grid tie inverters, 1000 volt equipment can be installed.						
53313	15A0724	ECNY Electric 42 West 38th Street, Suite #501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	X131-Albert Einstein 885 Bolton Avenue Bronx NY	Approved	\$650.00
OR With the stipulation that the installation complies with Section 690.17, Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 ER Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 OK, with the stipulation that: JAP6 72/295-315/3BB modules, Advanced Energy AE 3TL 1000 series 3 phase transformerless string inverters, conext CL-NA 3 phase grid tie inverters, 1000 volt equipment can be installed.						
	15A0726	Litespeed Electric 135 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	919 Third Avenue New York NY	Denied	\$650.00
1) Service switchboard's A and C service bus undersized to add new 2500 amp service switches to existing switchboards. 2) Coordination study not provided. 3) Confirm MI conversion 4) Provide room DIM.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0727	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Hudson Yards Retail Podium 500 West 33rd Street New York NY	On Hold	\$650.00
<p>1) Verify that switchboards comply with 408.60(F). 2) Provide short circuit study. 3) Drawing 2 verify feeder size to ATS-EO-8-C on normal side 4) Verify whether 750 KCM are aluminum or copper on 1 lines. 5) Drawing 3 section bus undersized in Section 9. 6) Drawing 3 2 1000 amp service switches to be ground fault protected. 7) Drawing 4 1200 amp service switch to be ground fault protected. 8) Drawing 5 show lengths and size of transformer secondary conductors. 9) Drawing 5 section bus undersized in section 4. 10) Drawign 6 show short circuit current at fire pump controller. 11) Drawing 7 show load bank on 1 Line ooff of 2500 amp switch, see cut sheet. 12) Drawing 7 verify ground fault indiction or generator main switch. 13) Drawing 7 5000 and 4000 amp generator switches not ground fault protected. 14) Clarify dotted lines, and ATS' ib 1 Line is the new work use solid Lines for all new work with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53456	15A0728	Patriot Electric Corp. 96-06 220th Street Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	445 Gold Street Brooklyn NY	Approved	\$650.00
Provide coordination study signed and stamped by a P.E. 1/22/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53317	15A0730	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	249 West 17th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53613	15A0732	M.C. Electrical NY, Inc. 835 Castleton Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	1460 Broadway New York NY	Approved	\$650.00
<p>1) Where is the new service end box located, service entrance conductors may have to comply with 230.6. 2) Verify fire pump switch size. 3) Remove L51G from 1600 generator switch. 4) Provide coordination study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/23/16 Job finalized. This drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/21/16 Rejected Fire alarm service switch need to be removed as its fronting service switch. 1/30/17 Swapped drawing 22134FP60-01 of 01-Revision 3.</p>						
	15A0734	A & M Electrical Services, Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	459 East 149th Street Bronx NY	Rejected	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/13/17 - Show the connection size inside the twin panel board HDP</p>						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0735	Top Shelf Electric Corporation 4386 Victory Boulevard Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	QPRD-Bldg. A 28-02 Jackson Avenue Queens NY	Denied	\$650.00
<p>1) Manufacturer's cut sheets of equipment not provided. 2) Cables to tower B2 to be terminated to a switch as per 225.32 not a pull box, same for B1, amendity buildings. 3) Network protector fan to comply with 230.79(D). Transformer secondary switches reversed. 4) Do not show anything after 2nd fusing on 1 Line drawing. Indicate types of ATS being used at Genet. 5) How do you terminate GEC #4-500 in 60 amp fire alarm service switch. 6) Show fusing sizes on designations 1 through 5, all other drawings. 7) How do 4/0 conductors terminate in 100 amp switch FA.? 8) Provide coordination study from a PE signed and stamped with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 9) Review stopped.</p>						
53337	15A0736	Nead Electric, Inc. 530 West 50th Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Nestle 430 East 29th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53314	15A0738	ECNY Electric 42 West 38th Street, Suite #501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	X192 Intermediate School 192 650 Hollywood Avenue Bronx NY	Approved	\$650.00
<p>OR With the stipulation that the installation complies with 690.17. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 ER Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 OK, with the stipulation that: JAP6 72/295-315/3BB modules, Advanced Energy AE 3TL 1000 series 3 phase transformerless string inverters, conext CL-NA 3 phase grid tie inverters, 1000 volt equipment can be installed.</p>						
53606	15A0739	Jacoby Electric Corp. 10-40 Borden Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Telx Generator Project 60 Hudson Street New York NY	Approved	\$650.00
1) Door to open outwards. 2) Comply w/CB setting for gen. 3/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53471	15A0740	Striano Electric Co., Inc. 42-24 Douglaston Parkway Douglaston NY 11363	Requested approval for the electric service equipment proposed to be installed	1015 Madison Avenue, 3rd Floor New York NY	Approved	\$650.00
1) Existing switchboard fed from fuse side of switch. 2) Show bonding and grounding of existing equipment. 3) Short circuit calculations don't match drawing provide PE stamp. 1/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/24/16 Swapped drawing B-Revision 2.						
53338	15A0741	Egg Electric Inc. 35 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Hospital of Queens 72-06 Northern Boulevard Queens NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53324	15A0742	Limongelli Electric Corp. 214-41 42nd Avenue, Fourth Floor Bayside NY 11361	Requested approval for the electric service equipment proposed to be installed	Avalon-Kips Bay 377 East 33rd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53619	15A0743	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	NYU-Cyclotron 660 1st Avenue New York NY	Approved	\$650.00
1) Verify that service room is mechanically ventilated. 2) Show FLA of existing fire pump. 3) Show supplemental grounds in each switchboard. 4) Show drip pan under waste pipes, elevation drawing. 3/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53474	15A0744	Bala Consulting Engineers 1 William Street, 2nd Floor New York NY 10004	Requested approval for the electric service equipment proposed to be installed	1585 Broadway New York NY	Approved	\$650.00
Confirm that reverse backward relay provided. 2/1/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/21/16 Swap Dwg AB-Revision 2 and Drawing PB-Rev 3.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53472	15A0745	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	NYU College of Dentistry 345 East 24th Street New York NY	Approved	\$650.00
Is this service in addition to another service and where is chiller located? 1/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/2/16 Swapped drawing A-Revision 2 and Drawing B-Revision 1.						
53458	15A0746	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	180 Water Street New York NY	Approved	\$650.00
<p>1) Bus on load side of transformer undersized, secondary disconnect exceed 4200 amps. 2) 1 Line doesn't match physical section on load side of transformer with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 1/26/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	15A0748	Team Electric, Inc. 20 West 36th Street, 10th Fl. New York NY 10019	Requested approval for the electric service equipment proposed to be installed	413 West 14th Street New York NY	Pending	\$650.00
1) 32 conductors in trough to comply with 376.22(B). 2) Show type of fuses being installed. 3) Tapped conductors undersized. 4) FLA not shown on 1 Line, service entrance conductors and EGC's to fire pump service switch undersized.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53339	15A0750	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission to utilize Article 690 of the 2014 NEC to allow the installation of listed 1000 volt solar photovoltaic equipment solar edge inverters models SE20kUS, SE10kUS, SE33.3US, solar Edge Power Optimizer P600, P700, Solar Bus combiners, LG-LG320NIC-64, LG315NIC-G4, L310NIC-G4 and LG305NIC-G4 modules on 45 buildings	See Comments for job addresses.	Approved	\$0.00
Code 110.2(B)(5) 6405, 6410, 64-30, 6419, 64-25, 64-36, 64-36, 64-39, 64-51, 67-09, 67-05, 6725, 67-36, 67-20, 69-40, 6902, 67-42, 69-30, 69-01, 69-09 and 67-35 186 Lane; 64-45, 64-50, 67-02, 67-25, 69-10 and 67-50 188th Street; 188-01 71 Circle; 188-15, 192-40, 190-19, 192-50, 192-65, 188-45, 192-35 and 192-45 71st Crescent; 190-06, 192-10, 190-38, 192-15 and 193-15 69th Avenue; 67-45, 67-44, 67-50 and 67-15 190th Lane. Fresh Meadows, NY 11365. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0751	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Hudson Yards-Tower A-Perm 500 West 33rd Street New York NY	On Hold	\$650.00
1) Drawing C-2 show conductors and wiring methods o line and load of fire alarm disconnect switch. 2) Service room verify supplemental ground is installed on the collector bus. 3) Verify if TA-EM-DS-10B(B) 800 A4BQ does not coordinate 225 TRS and same in panel TA-EM-DS-10 B(B), E-2. 5) Verify ATS TA ATS-11-1(TW) is 3 pole, not 4 pole, feeders on ATS is wrong on drawing E-2, and TA-ATS-10-6(TW) on drawing F2. 6) E-2 ss #4 not ground fault protected. 7) Drawing G-2 3000A A4BQ does not coordinate with 1600 A4BQ. 9) Verify size of chiller feeders. 10) Provide coordination study.						
53796	15A0752	Abraham Joselow P.C. 45 West 34th Street, Suite 1101 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Columbia University 411 West 116th Street New York NY	Approved	\$650.00
1) Wein Hall service room to be identified as electrical distribution room, and Con Edison service end box to be identified as 3000 amp copper detail box. 2) Show amount of copper bus bars in last section distribution panel. 3) Fire pump second fused, feeder undersized. 4) Two Con Ed meters shown in series. 5) Confirm that the new installation has EGS and no ground system bonding. 1) C.T. in Greene Hall to be bonded and grounded not service switch #3. 1/27/16 1. C.T. in Greene Hall to be bonded and grounded not service switch switch #3. 5/3/6 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53322	15A0753	Gunzer Electric, Inc. 36-36 34th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	2 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53462	15A0754	AMA Consulting Engineers, P.C. 250 West 39th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Chelsea Market 75 9th Avenue New York NY	Approved	\$650.00
Provide a second door as per 230.64(B)(5). 1/26/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53465	15A0755	E & M Electrical NY Corp. 193-02 Northern Blvd. Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	1230 Park Avenue New York NY	Approved	\$650.00
OR Verify bus size in 2000 amp service switch. 1/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0756	OM Electric, Inc. 262 West 38th Street, Suite 1202 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	9-19 9th Avenue New York NY	Administrative Closure	\$650.00
OR Show bus size for service switches 2,3,1 1/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/2/16 This job is void in lieu of Approval # 53466, Submittal #16A0454.						
53323	15A0757	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	7 East 15th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53461	15A0758	amdeens Electrical Contracting Corporatio 132 10A Liberty Avenue South Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	301 East 99th Street New York NY	Approved	\$650.00
a.k.a. 1922 2nd Avenue. 1) Confirm that there are two F.A. S.S. 2) Provide size for phase blocks. 1/26/16 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53340	15A0759	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	810 River Avenue Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53341	15A0760	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	Bam North Site II 280 Ashland Place Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53342	15A0761	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	1130 South Avenue Staten Island NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53343	15A0762	M.O.S Electrical Contracting Corp. 4304 Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	275-295 Locust Avenue Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53468	15A0763	Hanington Engineering Consultants 1 Gold Mine Road Flanders NJ 07836	Requested approval for the electric service equipment proposed to be installed	417 Park Avenue New York NY	Approved	\$650.00
Elevators must coordinate w/ upstream device current ration is 8:1. 1/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/31/16 Swapped drawings 1 and 2-Revision 2s.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53464	15A0764	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	250 South Street Brooklyn NY	Approved	\$650.00
1) Verify that service room is fire rated. 2) How long will temp service be in use? 1/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53344	15A0765	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	36 Bleeker Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53526	15A0766	Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	60 Water Street Brooklyn NY	Approved	\$650.00
1) Service room to be mechanically ventilated. 2) Equipment grounding conductor for fire pump feeder undersized. 3) Show short curve between 1600 amp A4BQ and 400 amp circuit breaker, show fault current at breaker. 4) Verify that 6000 amp service switch and 6000 amp fuses are listed. 5) Verify sizes of service switch 4 and 5, between service room and 1 Line. 2/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53321	15A0768	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Medical College 1305 York Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0769	A & M Electrical Services, Inc. 617 Johnson Avenue Brooklyn NY 11237	Requested approval for the electric service equipment proposed to be installed	1770 Madison Avenue New York NY	On Hold	\$650.00
1) Is this submittal a duplicate filing, if yes, put note on drawing to void first submittal. 2) Service switch size not shown in switchboard and amount of bus not shown supplying service switch, show fuse type. 3) Provide letter from utility showing fault current. 4) Show fault current at meter banks, meter bank and circuit breaker cut sheets. 5) Equipment grounding conductor for fire pump feeder undersized. 6) Provide coordination study.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0770	Roz-A-Lite Electrical Contracting Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	325 Lexington Avenue New York NY	Denied	\$650.00
1) Service trough not shown in service room. 2) More than 40 conductors in service trough, size of trough not shown, and taps being made in trough. 3) Review stopped.						
53545	15A0771	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	589 Fifth Avenue New York NY	Approved	\$650.00
Verify that existing meter does not block existing 1600A switch. 2/19/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53551	15A0772	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	115 Delancey Street New York NY	Approved	\$650.00
1) Provide approval # for 1st submittal. 2) Through bus overfused. 3) Provide protection for side of switchboard. 4) Work clearance to be measured from edge of Bollard. 2/24/16 Job finalized. This voids 15A0545., no approval #. Ok. With the stipulation that the front clearance of the service equipment starts at the inside side of the Bollards to the front of the service equipment. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53345	15A0773	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Hudson Yards Tower A-Temp 500 West 33rd Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0774	Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	3 Mitchell Place New York NY	On Hold	\$650.00
New work to be bubbled in service room and 1 Line drawing, not reviewed.						

ADVISORY BOARD CALENDAR

November 18, 2015

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53320	15A0775	Rail Electric, Inc. 54-53 71st Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	38 East 19th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53470	15A0776	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	390 Madison Avenue New York NY	Approved	\$650.00
1) Secondary of transformers overfused. 2) Primary switch to be rated for in rush current. 3) Reconfigure switchboard 1 to eliminate the dead ended space. 1/28/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0777	Denmar Electric Corp. 5 Penn Plaza, 19th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital 199 Mount Eden Parkway Bronx NY	Pending	\$650.00
<p>1) Wiring method to DSB-B. Not shown on 1 Line. 2) Show size of equipment grounding conductors in the MC cable. 3) Verify that generator is separately derived system, if yes show neutral bond at generator. 4) Show feeder size and wiring methods to ATS switches. 5) One line doesn't match physical in DSB-A with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/24/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements . 7/28/16 1. Equipment grounding conductors for 1600 & 300 Amps feeders are undersized, void out prviously submittal 10A0404 A#50386. This submittal 15A0777 with A# 53936 is changed to pending due to item #2 not addressed.</p>						