

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 112-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue,
St. Charles, IL. 60174

Trade Name(s) - System Sensor, Honeywell.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S2101, Project 99NK37501, Volume 5, Section 1, issued
January 12, 2000.

Description - System Sensor's heat detector rated at 135°F as follows:

Model No.	Description
TC808B1002	Electronic fixed temperature heat detector
TC808B1010	Electronic Rate-of-Rise with fixed temperature heat detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objection letter dated April 24, 2000, F.P. Index #0004019.

Recommendation - That the above heat detectors be accepted on conditions that all uses, configurations, arrangements and functions, applications and installations comply with the provisions of New York City Building Code, specifically Subchapter 17, and with the Reference Standards RS 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72E and UL listing. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance October 24, 2000

Examined By Mark J. Kelly