



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 113-05-E Vol. 3

Manufacturer: Kidde-Fenwal, Inc., 400 Main Street. Ashland, MA 01721

Trade Name(s): Fenwal®, Kidde®

Product: Fire alarm equipment
MEA Index #280 – Fire Alarm Equipment

Pertinent Code Section(s): 27-968 through 27-981, Reference Standard RS 17

Prescribed Test(s): §27-969 (UL 864)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S3743, Project 05NK24034, issued December 12, 2006 and revised December 13, 2007.

Description: Model 73-100001-003 Addressable AlarmLine Module (AAM) is a SmartOne device used with the FenwalNET 2000, FenwalNET 6000, Kidde PEGAsys and Kidde ARIES intelligent control panels.

The AlarmLine Addressable Linear Heat Detector provides early detection of fire or overheated conditions in protected areas or equipment. It is specially suited for confined areas or environments where adverse conditions cause other detection devices to be unreliable or difficult to use.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated March 3, 2008, F.P. Index #s: 0802042 & 0802043).

Terms and Conditions: The above-described addressable fire alarm equipment is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17. Further, the installation shall be in accordance with the manufacturer's recommendations, NFPA 72 and UL standard.
2. The above product shall be used only with compatible, listed and approved AlarmLine Sensor Cables and fire alarm control panels with which the compatibility has been determined to be acceptable by a UL test report.
3. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 20, 2008

Examined BY Donald [Signature]