

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 116-04-E

Report of Materials and Equipment Acceptance Division

Manufacturer – Rheem Manufacturing Company, A/C Division, P.O. Box 17010, Fort Smith, AR 72917.

Trade Name – Rheem.

Product – Packaged air conditioning units.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Tests – RS 13-11 (UL 1995), RS 13-6 (ANSI B9.1).

Laboratory – Underwriters Laboratories Inc.

Test Report – UL File SA9930 dated January 7, 1998, revised July 18, 2001.

Description – Packaged self-contained air condition units, for indoor installation and for use with ductwork connected to conditioning space. R-22 is the refrigerant used for the system. Unit comprises hermetically sealed compressor, air cooled condenser or water cooled evaporator and blower and controls. Units, with model numbers and nominal cooling capacities, are listed below.

Model No.	Nominal Cooling Capacity Rating, Tons
RLNB A-102*	7.5
RLNB A-180*	15.0

Note: * for additional suffixes in model numbers.

Recommendation - That the above described packaged air conditioning units be accepted for indoor installation, when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, Subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 6/25/04

Examined by Shyam. Prasad