

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 118-00-E

Report of Material and Equipment Acceptance Division

Manufacturer – Heatilator, 1915 West Saunders, Mt. Pleasant, Iowa 52641.

Trade Name – Heatilator.

Product – Gas fired decorative log appliance.

Pertinent Code Section(s) – 27-800.

Prescribed Test(s) - RS 14-6 (ANSI Z21.60-1996, ANSI Z21.50-1998).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File MH15519, dated April 20, 2000.

Description – Model ODY42 is a decorative vented gas-fired fireplace with factory installed decorative gas log. Its dimensions are 49 1/2" (depth) by 41 5/8" (height) by 23" (depth) with bi-fold glass doors.

Model No.	Rating BTUH
ODY42	75,000

Recommendation - That the above described gas fired log appliance, be accepted for use in vented fireplaces only, for decorative heating operation on natural gas and for indoor installation only with combustion air and required ventilation air provided. Venting of the fireplace is subject to Section 27-879 of the Building Code. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/27/2000
Examined By S.M. Moran