



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 120-06-E

**Manufacturer:** Fire-Lite Alarms. One Fire-Lite place, Northford, CT 07642

**Trade Name(s):** Fire-Lite Alarms

**Product:** Fire Alarm Control panel with internal digital alarm communicator transmitter (DACT)

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS 17

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S624, projects 02ME20023A, 05NK12950 and 05ME154552 issued March 26, 2003, revised January 17, 2006.

**Description** – The MS-9200UDLS and MS-9200UDLSE are both 198 point addressable fire alarm control panels with integral two-line digital alarm communicator transmitter (DACT). The units are identical to Models MS-9200UD and MS-9200UDE except for the use of a larger enclosure.

Model No.	Description
MS-9200UDLS	Fire Alarm Control Panel
MS-9200UDLSE	Fire Alarm Control Panel

Pursuant to "Promulgation of the Rules to Material and Equipment Application Procedures" dated November 5, 1992 the Bureau of Fire Prevention has no objection letter dated March 13, 2006, F.P. Index No#: 0603006.

**Terms and Conditions:** That the above units be accepted on condition that:

1. All, uses, configurations, arrangements, functions, applications, and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3, 17-3A, 17-3B, 17-3C and 17-5. Further, the installation shall be in accordance with the manufacturer's recommendations and UL Standard.
2. The installation of Fire Alarm Control Unit must provide for fail-safe operation. This feature must assure that control of doors, locks, ventilation fans, and elevator recall will not be rendered inoperable in the event of a fire or power failure.
3. These control units when used with central office communicator or transmitter, the installation and operation of the equipment and devices shall comply with 3RCNY 17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler water flow alarm, supervisory signal indications and trouble indications.
4. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
5. Installation of pre-recorded evacuation messages in the fire alarm control unit would require a prior approval from the Department.
6. All above referenced fire alarm equipment shall be painted red in color.
7. The above referenced fire alarm control units shall be used only with listed, approved or accepted equipments and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.

All shipment and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 27, 2006.  
Examined by Donald [Signature]