



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 120-06-E Vol. 2

**Manufacturer:** Fire-Lite Alarms, One Fire-Lite Place, Northford, CT 07642

**Trade Name(s):** Notifier

**Product:** Fire alarm control panel with internal digital alarm communicator transmitter (DACT)

**Pertinent Code Section(s):** §27-968 through §27-981, and Reference Standard RS 17

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL Multiple Listing File S635, issued October 12, 1987, revised February 6, 2006.

**Description:** The Fire Warden-100-2 is a 198-point addressable fire alarm control panel with integral two-line digital alarm communicator/transmitter (DACT). This Fire Warden-100-2 is multiple listed with Fire-Life Model MS-9200 UDLS, approved under MEA 120-06-E.

Notifier Model No.	Fire-Lite Model No.	Description
Fire Warden-100-2	MS-9200 UDLS	Fire Alarm Control Panel

**Terms and Conditions:** The above units are accepted on the following conditions that:

1. All uses, configurations, arrangements, functions, applications, and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards 17-3, 17-3A, 17-3B, 17-3C and 17-5. Further, the installation shall be in accordance with the manufacturer's recommendations and UL Standard.
2. When these control units are used with central office communicator or transmitter, the installation and operation of the equipment and devices shall comply with 3RCNY 17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler water flow alarm, supervisory signal indications and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
4. Installation of pre-recorded evacuation messages in the fire alarm control unit shall require a prior approval from the Department.
5. All above referenced fire alarm equipment shall be painted red in color.
6. The above-referenced fire alarm control units shall be used only with listed, approved or accepted equipments and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.
7. All shipment and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 23, 2006  
Examined By Donald [Signature]