

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47883CO2	07A0257CO2	Polo Electric Corp. 497 Canal Street New York NY	Requested approval for the electric service equipment proposed to be installed	148 Lafayette Street New York NY	Approved	\$0.00
Carry over from November 12, 2008 meeting. 1) Explain purpose of fire pump ATS if no generator. 2) Doors to swing out. Job finalized 2/18/09.						
48637CO2	08A0202CO	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Verizon 375 Pearl Street, 8th Floor New York NY	Approved	\$0.00
Carry over from April 16, 2008 meeting.						
48951CO	08A0435CO	Kleinknecht Electric Company, Inc. 242 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	NYU Stern School 40 West 4th Street New York NY	Approved	\$0.00
Carry over from September 17, 2008 meeting.						
49040CO	08A0509CO	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NY Presbyterian Hospital 5141 Broadway New York NY	Approved	\$0.00
Carry over from October 15, 2008 meeting.						
49041CO2	08A0510CO2	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	184 Kent Avenue Brooklyn NY	Approved	\$0.00
Carry over from October 15, 2008 meeting.						

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49085CO	08A0540CO	LTC Electrical Contracting LLC 47-10 104th Street Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	Gateway II 2088 Lexington Avenue New York NY	Approved	\$0.00
Carry over from November 12, 2008 meeting.						
49099CO	08A0554CO	Ark Systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The New Family Intake Center 151 East 151st Street Bronx NY	Approved	\$0.00
Carry over from November 12, 2008 meeting.						
49102CO	08A0557CO	BGA Engineering, LLC 99 Bauer Drive Oakland NJ 07436	Requested approval for the electric service equipment proposed to be installed	4 Irving Place New York NY	Approved	\$0.00
Carry over from November 12, 2008 meeting.						
49140	08A0582	M.R. Electrical Service, LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	114-124 Troutman Street Brooklyn NY	Approved	\$650.00
Provide manufacturer submittal for new service equipment(GE). Job finalized 12/10/08.						
49141	08A0583	Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	111 Fulton Street New York NY	Approved	\$650.00
1) Show details of what's feeding new 800 amp service panelboard. 2) New Time Warner service switch outside service room. Relocate in service room or request special permission. Job finalized 2/17/09.						

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49142	08A0584	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Salvation Army 62 Hansen Place Brooklyn NY	Ok, but	\$650.00
Correct typo 800A fuse is KRPC not LPNR.						
49143	08A0585	Gilston Electrical Maintenance Corp. 453 East 175th Street Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	301 West 118th Street New York NY	Approved	\$650.00
49144	08A0586	Jorob Contracting and Electrical Co. Inc. 104-29 Jamaica Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	USPS-APC Lobby 84 Front Street Brooklyn NY	Approved	\$650.00
Provide size of 400A feeder. Job finalized December 17, 2008						
49145	08A0587	MetroYork Electrical, Inc. 23-86 BQE Long Island City NY 11103	Requested approval for the electric service equipment proposed to be installed	Lion House Recons-Bronx Zoo 2319 Southern Boulevard Bronx NY	Approved	\$650.00
Service room doors to swing out. Job finalized 2/17/09.						
49146	08A0588	June Safety Electrical, Inc. 1184 60th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Vesta Astoria 19-73 38th Street Queens NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49147	08A0589	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Cobble Hill Health Center 380 Henry Street Brooklyn NY	Approved	\$650.00
FACO and fire pump service switches tapped on line side of CT. Job finalized 3/3/09.						
49148	08A0590	Power Master Electrical Contracting, Inc. 152 Madison Avenue, Suite 1106 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	724 Fifth Avenue New York NY	Approved	\$650.00
49149	08A0591	Cerrito Electric of New York, Inc. 85-45 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Building "1A" 164 Kent Avenue Brooklyn NY	Approved	\$650.00
49150	08A0592	Urban Serwell, Inc. 856 East 136th Street, 1st Floor Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	131 West 33rd Street New York NY	Approved	\$650.00
49151	08A0593	Kleinberg Electric Inc. 437 West 16th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	Lincoln High School 2800 Ocean Parkway Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49152	08A0594	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	808 Columbus Avenue New York NY	Approved	\$650.00
49153	08A0595	Maximum Electrical Contracting Corp. 708 Mace Avenue Bronx NY 10467	Requested approval for the electric service equipment proposed to be installed	339-343 West 36th Street New York NY	Approved	\$650.00
49154	08A0596	Associated Electrical Contrs of NY, Inc. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	2025 Seward Avenue Bronx NY	Approved	\$650.00
Provide code required code required clearances. Job finalized 3/30/09.						
49155	08A0597	T & R Alarm Electrical Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	250 Bedford Park Boulevard West Bronx NY	Hold	\$650.00
1) Drawings not submitted in Advisory Board format. 2) Show what work is new and what is existing. 3) Service entrance equipment grounding conductors undersized. 4) FCO not properly bonded. 5) Equipment grounding conductors on load side of service switch undersized. 6) Bus sizes not provided. 7) Fuse types not provided. 8) Coordination between fuses not shown. 9) AIC not provided.						
49156	08A0598	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Central Park Zoo 10 Central Park New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49157	08A0599	A & R Electrical Maintenance, Inc. 64-14 69th Place Middle Village NY 11379	Requested approval for the electric service equipment proposed to be installed	88 Morningside Avenue New York NY	Approved	\$650.00
1) Conductors feeding MB-B and MB-A are overfused. 2) Fusing undersized in fire pump service switch. 3) Provide size of feeders between TDP Section 1 and 2. 4) Indicate fuse manufacturer and types. Job finalized 07/09/09.						
49158	08A0600	Levinson & Santoro Electric Corp. 18-20 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	PS 214 1970 West Farms Road Bronx NY	Approved	\$650.00
49159	08A0601	Contact Electric Corp. 3561 12th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	117 Kent Avenue Brooklyn NY	Ok, but	\$650.00
1) Service room doors to open outwards. 2) Provide type of overcurrent protection devices used in meterbanks 1, 2 and 3.						
49160	08A0602	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	Goldman Sachs BPC-Site 26 New York NY	Hold	\$650.00
1) Is all work? 2) Verify if battery room is vented. 3) Confirm generator neutral is grounded. 4) Only life safety breakers in ASCO switch to have GF indication, all others 1000A and above to have GF trip. 5) Main generator breakers cannot have GF trip since they service life safety loads. (ASCO). 6) How is current on main bus limited to 10,000A?(ASCO) 7) Only short circuit study submitted. Submit coordination curves. 8) Have engineer appear to explain UPS system switchgear operation.						
49161	08A0603	C.M.S. Electrical Services Co.Inc. 306 West 37th Street, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Equity Offie Properties 717 5th Avenue New York NY	Hold	\$650.00
1) Fire pump service to be upgraded with a separate service switch and fire rated fire pump conductors. 2) Room layout must be provided.						

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49162	08A0604	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	5802 3rd Avenue Brooklyn NY	Approved	\$650.00
1) Show service entrance conductors for service switch #6. 2) Explain how 2 sets of 500 MCM will terminate on 400A main breaker protected by 800 amp service switch fuse. 3) Neutral bonded to enclosure on existing 400 amp disconnect switch and new 400 amp panel.. 4) Why 2000 amp fuses reduced to 800 amps. Job finalized 1/2/09.						
49163	08A0605	Solar Electric Systems Inc. 452 West 55 Street New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Queens Borough Public Library  Queens NY	Hold	\$650.00
1) Fire pump emergency feeder to be rated. 2) Show coordination between 1st and 2nd fusing. 3) Provide bus sizes in panelboards. 4) Connect fire and jockey pump in junction box after ATS. 5) Provide short circuit calculations.						
49164	08A0606	Dal Electrical Corp. 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	NYU-The Silk Building 14 East 4th Street New York NY	Approved	\$650.00
49165	08A0607	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Willoughby Rehab & Health Ctr 660 Louisiana Avenue Brooklyn NY	Approved	\$650.00
49166	08A0608	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	5355 Henry Hudson Parkway Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49167	08A0609	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Gotham Center-Building B2 42-09 28th Street Long Island City NY	Hold	\$650.00
1) Drawing C neutral bond in transformer is in 2 locations. 2) Show section view terminations of 13 sets of conductors on load side. 3) Show separatin of service bus and load calculations.						
49168	08A0610	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	200 Eleventh Avenue New York NY	Approved	\$650.00
49169	08A0611	A.P.E. Electrical, Inc. of NY & NJ 581 Amboy Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	142 North 6th Street Brooklyn NY	Approved	\$650.00
49170	08A0612	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Courtlandt Corners II 361 East 161st Street Bronx NY	Approved	\$650.00
1) Increase bus size that feeds the 2-1600 amp disconnect switches. 2) Commercial trough tap is undersized. Job finalized 2/18/09.						
49171	08A0613	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Newsweek 395 Hudson Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49172	08A0614	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	653 11th Avenue New York NY	Approved	\$650.00
49173	08A0615	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	225 Varick Street New York NY	Approved	\$650.00
49174	08A0616	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Dream Downtown 346 West 17th Street New York NY	Approved	\$650.00
49175	08A0617	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	McClancy High School 71-06 31st Avenue East Elmhurst NY	Approved	\$650.00
49176	08A0618	ID Electric Corp. 36-17 Bud Place Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	4901 Henry Hudson Parkway Bronx NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49177	08A0619	T & R Alarm and Electrical Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	120-55 Queens Blvd. Queens NY	Denied	\$650.00
1) Drawings not submitted in Advisory Board format. 2) Fuse coordination not shown. 3) Fuse types not shown. 4) Service room layout not provided. 5) Job address not provided.						
49178	08A0620	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Van Nest School 1640 Bronxdale Avenue Bronx NY	Approved	\$650.00
1) Bus and fuse size printing too small to read, larger printing required in the future. 2) Neutral in generator to be bonded to enclosure and ground conductor to go to water main. 3) Provide manufacturer's cut sheets of panels. Job finalized 2/18/09.						
49179	08A0621	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue New York NY	Hold	\$650.00
1) Drawings not submitted in Advisory Board format. 2) Printing on drawing too small to read. 3) Identify what work is new and existing. 4) Provide cut sheets of equipment. 5) Detail what work will be done by others. 6) Coordinatin not provided.						
49180	08A0622	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS 200 2589 7th Avenue New York NY	Ok, but	\$650.00
1) 3/O equipment grounding conductor undersized for 1600 amp fusing. 2) Provide signage on each service room door.						
49181	08A0623	Scientific Electric Company, Inc. 1475 East 222nd Street Bronx NY 10469	Requested approval for the electric service equipment proposed to be installed	52 East 4th Street New York NY	Approved	\$650.00
Fuses do not coordinate. Job finalized 2/18/09.						

# ADVISORY BOARD CALENDAR

December 10, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49182	08A0624	Primiano Electric Co. 599 11th Avenue, 6th Floor New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Hyatt Hotel 485 5th Avenue New York NY	Approved	\$650.00
1) Bus duct overfused. 2) Verify if 3 or 4 pole ATS' are used. 3) Provide tap detail in café metro trough. 4) Show bus sizes for line side of 2500 and 2000 disconnect switches. 5) Load side bus in 2500 amp disconnect switch undersized. 6) Transformers secondaries not bonded. 7) Service entrance feeding 800 amp service switch undersized. 8) Provide short circuit calculation and curves for panelboards. Job finalized 6/22/10.						
49183	08A0625	Eldor Electric, LLC 18-15 129th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Tallman Island, WPCP 127-01 Powells Cove Boulevard College Point NY	Hold	\$650.00
1) Explain how the bus is made 4-1.63, 2x1.63. 2) Is a fire pump and fire alarm being installed? 3) Special permission needed for not providing full selectivity and state that there is no life safety equipment						
49184	08A0626	JMC Electric Corp. 172-02 39th Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	370 Park Avenue New York NY	Hold	\$650.00
1) Provide documentation the PTC is listed equipment. 2) Provide fused disconnect switch that the generator will feed prior to the PTC. 3) Provide sequence of operation between main 400 amp breaker and 2-200 amp breakers.						
49185		Approved Electrical Contractors, Inc. 6318 New Utrecht Avenue Brooklyn NY 11219	Requesting permission to leave as installed eight sets of 500 MCM service entrance conductors feeding a 4000 amp service switch that will be fused at 3000 amps with permanent signage affixed to the switch stating maximum fuse size permitted is 3000 amps,	Wartburg Lutherran Nursing Home 50 Sheffield Avenue Brooklyn NY	Approved	\$350.00
49186		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requesting permission to leave as installed approximately 235 fluorescent fixtures wired without ballast disconnect devices.	1250 Waters Place Bronx NY	Hold	\$0.00
Contractor to provide purchase order confirming that the fixtures were ordered prior to January 1st, 2008.						

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49187		Nee Electrical, LLC 74 Calyer Street Brooklyn NY 11222	Requesting permission to replace ten elevator non spliced feeders in existing elevator shaftways due to vandalism of the feeders being installed in the hallways.	New York City Housing Authority Vladek 1 Houses New York NY	Approved	\$0.00
49188		Associated Electrl Contrs of N.Y. Corp. 27 East 233rd Street Bronx NY 10470	Requesting permission to install a seventh service switch where one of the existing service switches provides power to a fire pump and to allow a 4' clearance for service switches installed facing each other on a 1000 KVA installation.	2025 Seward Avenue Bronx NY	Approved	\$0.00
to install a 7th service switch with the stipulation that the service equipment is relocated to provide the Advisory Board required clearances.						
49189		Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to run 8 sets of 500 MCM service entrance conductors in E.M.T. sheet rock encased approximately 27 feet from the end box to a temporary 4000 amp service switch board room in a new building where there is no other location to place this service, the temporary service will remain in use for approximately 1 year to 14 months.	400 5th Avenue New York NY	Approved	\$0.00
49190		Crana Electric Inc. 600A East 132nd Street, 2nd Floor Bronx NY 10454	Requesting permission to install overcurrent protective devices for a meter bank approximately 81 inches off of the finished floor	333 Rector Place New York NY	Approved	\$0.00
with the stipulation that QP type circuit breakers are installed.						
49191	08A0627	Lightolier 631 Airport Road Fall River NY 02745	Request approval for use in New York City of your Energy Efficient Recessed Compact Fluorescent IC Luminaire-ceiling or wall mount. Model/Series Numbers: 1050 Series		Approved	\$200.00

# ADVISORY BOARD CALENDAR

**December 10, 2008**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49192	08A0628	Lithonia Lighting 2 Lithonia Way Conyers GA 30012	Requested approval for use in New York City of your Fluorescent Retrofit Kits. Model/Serial Numbers: RT5R, ES8R.		Approved	\$200.00
49193	08A0629	American Power Conversion Corp. 85 Rangeway Road North Billerica MA 01862	Requested approval for use in New York City of your Uninterruptible Power Supply with Accessories. Model/Serial Numbers: Symmetra PX 250KW/500KW		Approved	\$200.00
49194	08A0630	Tecniver S.A., St Gobain Glass Solution 1 de Mornimont, 5190 Jemeppe-Sur-Sambre Belgium	Requested approval for use in New York City of your Privalite Privacy Glass Installation		Denied	\$200.00
The product must be tested and listed as a complete assembly by a nationally recognized testing laboratory(NRTL)						