

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|---|--------------|---|--|--|----------|----------|
| 49810CO   | 09A0468CO    | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416      | Requested approval for the electric service equipment proposed to be installed | One World Trade Center-Tower<br>New York NY                    | Hold     | \$0.00   |
| Carry over from November 18, 2009 meeting   |              |   |  |  |          |          |
| 49819CO   | 09A0477CO    | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416      | Requested approval for the electric service equipment proposed to be installed | Long Island Jewish Hospital<br>270-27 76th Avenue<br>Queens NY | Approved | \$0.00   |
| Carry over from November 18, 2009 meeting. Coordination study showing GF is coordinated. Job finalized 1/20/11. |              |   |  |  |          |          |
| 49855   | 09A0495      | Evergreen Electrical Corp.<br>133 50th Street<br>Brooklyn NY 11232          | Requested approval for the electric service equipment proposed to be installed | Katan Group<br>122 West Street<br>Brooklyn NY                  | Approved | \$650.00 |
| Provide neutral disconnect link for SS#2, 3, 4. Job finalized 3/5/10.   |              |   |  |  |          |          |
| 49856   | 09A0496      | Accurate Electric Corp.<br>4319 18th Avenue<br>Brooklyn NY 11218            | Requested approval for the electric service equipment proposed to be installed | 2 Franklin Street<br>Brooklyn NY                               | Approved | \$650.00 |
|   |              |   |  |  |          |          |
| 49857   | 09A0497      | Atlas-Acon Electric Service Corp.<br>283 Hudson Street<br>New York NY 10013 | Requested approval for the electric service equipment proposed to be installed | 300 East 42nd Street<br>New York NY                            | Approved | \$650.00 |
|   |              |   |  |  |          |          |

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar #   | Submission # | Applicant Name and Address  | Type of Request  | Installation Location   | Status   | Fee      |
|--|--------------|---|--|---|----------|----------|
| 49858  | 09A0498      | Gateway Electric Group, LLC<br>11-02 37th Avenue<br>Long Island City NY 11101             | Requested approval for the electric service equipment proposed to be installed | 180 Madison Avenue<br>New York NY   | Approved | \$650.00 |
| Verify if service room door can open outwards w/panic hardware. Job finalized 1/19/10.   |              |   |  |   |          |          |
| 49859  | 09A0499      | Corporate Electric Group, Inc.<br>14-34 110th Street, Suite 201<br>College Point NY 11356 | Requested approval for the electric service equipment proposed to be installed | Port Authority of NY/NJ Bus Ter<br>42nd Street & Eighth Avenue<br>New York NY | Approved | \$650.00 |
| 49860  | 09A0500      | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416                    | Requested approval for the electric service equipment proposed to be installed | New Settlement Comm. Campus<br>1501 Jerome Avenue<br>Bronx NY                 | Approved | \$650.00 |
| 1) Why is neutral bonded in generator:? Are 3 or 4 pole ATS' being used off of EDP-R-W? 2) Provide neutral disconnect links. 3) MSB-GE-LV to be shown as 4w. 4) Confirm FP MC cable is adequate for 125% FP FLA.. Job finalized 1/19/10.           |              |   |  |   |          |          |
| 49861  | 09A0501      | Allran Electric of New York<br>120 Broadway, 38th Floor<br>New York NY 10271              | Requested approval for the electric service equipment proposed to be installed | Milford Plaza Hotel<br>700 8th Avenue<br>New York NY                          | Ok, but  | \$650.00 |
| 1) How are 3 sets of 600 terminated in 400 amp switch. 2) How is jockey pump being tapped. 3) Service bus undersized SBD-1. For 3-1200 amp service switches, SBD-2. 4) Emergency side, provide sizes of switches and types of ATS being installed. |              |   |  |   |          |          |
| 49862  | 09A0502      | Robert B. Samuels Inc.<br>48 West 25th Street<br>New York NY 10010                        | Requested approval for the electric service equipment proposed to be installed | PTC-Trinity Real Estate<br>205 Hudson Street<br>New York NY                   | Approved | \$650.00 |

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar #  | Submission # | Applicant Name and Address  | Type of Request  | Installation Location  | Status   | Fee      |
|---|--------------|---|--|--|----------|----------|
| 49863   | 09A0503      | Sant-Tec Electric Inc.<br>305 East 110th Street<br>New York NY 10029                              | Requested approval for the electric service equipment proposed to be installed | The Claremont<br>1421 College Avenue<br>Bronx NY                 | Hold     | \$650.00 |
| 1) Tap conductors off of 1200 amp fuses are undersized. 2) Equipment grounding conductors off of 1200 amp fuse are undersized. 3) Neutrals are bonded to enclosure after service switch. 4) Verify fire pump information 800 amp service switch and 3/0 wire. 5) TR fuses on trough switches do not coordinated w/service fuse. 6) Confirm MI for FP feed can be installed in 2" c. |              |   |  |  |          |          |
| 49864   | 09A0504      | Adco Electrical Corporation<br>201 Edward Curry Avenue<br>Staten Island NY 10314                  | Requested approval for the electric service equipment proposed to be installed | Park Avenue Plaza<br>55 East 52nd Street-Basement<br>New York NY | Ok, but  | \$650.00 |
| 1) Fire alarm cutout neutrals are bonded to enclosures. 2) FCO equipment grounding conductor undersized. 3) Gen. FCO to be made ahead gen MCB.  |              |   |  |  |          |          |
| 49865   | 09A0505      | erified Electrical & Technical Services, In<br>27 Williams Street, Suite 409<br>New York NY 10005 | Requested approval for the electric service equipment proposed to be installed | 110 West End Avenue<br>New York NY                               | Approved | \$650.00 |
|   |              |   |  |  |          |          |
| 49866   | 09A0506      | Robert B. Samuels Inc.<br>48 West 25th Street<br>New York NY 10010                                | Requested approval for the electric service equipment proposed to be installed | 909 Third Avenue<br>New York NY                                  | Approved | \$650.00 |
| Confirm ATS 2 is 4 pole. Job finalized 1/19/10.   |              |   |  |  |          |          |
| 49867   | 09A0507      | Redline Electric Inc.<br>1715 East 9th Street<br>Brooklyn NY 11223                                | Requested approval for the electric service equipment proposed to be installed | 112-09 14th Avenue<br>College Point NY                           | Approved | \$650.00 |
| 1) Neutral in new 800 amp disconnect switch is bonded to enclosure. 2) Show entire service room on layout drawing. 3) Confirm stair access is maintained. Job finalized 3/1/10.   |              |   |  |  |          |          |

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location  | Status   | Fee      |
|---|--------------|--|--|--|----------|----------|
| 49868   | 09A0508      | Forest Electric Corp.<br>Two Pennsylvania Plaza, 4th Floor<br>New York NY 10121      | Requested approval for the electric service equipment proposed to be installed | NYPD-Joint Operations Comma<br>109 Park Row<br>New York NY       | Approved | \$650.00 |
| 1) Show neutral bonds in FCO boxes. 2) Show conductors on load side of ATS 2, 3, and 4. 3) Ground generator building steel. 4) Verify that ATS-1 and ss-emp does not supply life safety loads. 4) Confirm emergency wiring complies with 700.7(D)(1). Job finalized 10/21/10.   |              |  |  |  |          |          |
| 49869   | 09A0509      | Jeco Electrical Service Corp.<br>1162 Intervale Avenue<br>Bronx NY 10459             | Requested approval for the electric service equipment proposed to be installed | 3044 3rd Avenue<br>Bronx NY                                      | Approved | \$650.00 |
|   |              |  |  |  |          |          |
| 49870   | 09A0511      | Atlas-Acon Electric Service Corp.<br>283 Hudson Street<br>New York NY 10013          | Requested approval for the electric service equipment proposed to be installed | Trinity Real Estate<br>350 Hudson Street<br>New York NY          | Approved | \$650.00 |
| 1) Provide barriers in switchgear. 2) TVSS conection to be shown. 3) Show intake bus size. Job finalized 1/19/10.   |              |  |  |  |          |          |
| 49871   | 09A0512      | B & G Electl Contrs of NY, Inc.<br>38-22 55th Street<br>Woodside NY 11377            | Requested approval for the electric service equipment proposed to be installed | Gourverneur Health Services<br>277 Madison Street<br>New York NY | Hold     | \$650.00 |
| 1) Show clearances in service room. 2) Indicate front of switchboards in service room. 3) Verify that service room is ventilated. 4) Verify if service room has doors. 5) Neutral in service switches bonded to enclosure on load side of neutral link. 6) Neutral links not provided in 4000 and 3000 service switches. 7) Existing switchboard #1 not shown. 8) FACO #2 fused at 150 amps. 9) 480 volt ATS used for 120/208V. 10) Equipment grounding conductor undersized on line and load of fire pump conductors. 11) Equipment grounding conductor undersized on load side of 4000 amp fuse. 12) Emergency feeders on load side 2000 amp fuse not identified. 13) Wrong address in title box. |              |  |  |  |          |          |
| 49872   | 09A0513      | Caruso & Sons Electrical Contracting, Inc.<br>1489 Blondell Avenue<br>Bronx NY 10461 | Requested approval for the electric service equipment proposed to be installed | Time Warner Cable<br>5120 Broadway<br>New York NY                | Approved | \$650.00 |
|   |              |  |  |  |          |          |

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location                                 | Status   | Fee      |
|---|--------------|--|--|---|----------|----------|
| 49873   | 09A0514      | Zwicker Electric co., Inc.<br>360 Park Avenue South<br>New York NY 10010 | Requested approval for the electric service equipment proposed to be installed | 2148 Broadway<br>New York NY                          | Approved | \$650.00 |
| MSB-copper bus undersized in 1600 amp service switch. Job finalized 1/19/2010.  |              |  |  |   |          |          |
| 49874   | 09A0515      | Tarusis Electric Corp.<br>36-08 Ninth Street<br>Long Island City NY      | Requested approval for the electric service equipment proposed to be installed | Lehman High School<br>3000 Tremont Avenue<br>Bronx NY | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 49875   | 09A0516      | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416   | Requested approval for the electric service equipment proposed to be installed | P.S./I.S. 277Q<br>153-27 88th Avenue<br>Queens NY     | Approved | \$650.00 |
| Verify if panel EDP feeds life safety equipment. Job finalized 3/28/12.         |              |  |  |   |          |          |
| 49876   | 09A0517      | Chaim Electric Corporation<br>2920 Avenue J<br>Brooklyn NY 11210         | Requested approval for the electric service equipment proposed to be installed | 601 East 156th Street<br>Bronx NY                     | Approved | \$650.00 |
|   |              |  |  |   |          |          |
| 49877   | 09A0518      | Five Star Electric Corp.<br>101-32 101st Street<br>Ozone Park NY 11416   | Requested approval for the electric service equipment proposed to be installed | 505 West 37th Street<br>New York NY                   | Approved | \$650.00 |
| Indicate system voltage on drawing(not shown on 1-line). Job finalized 1/19/10. |              |  |  |   |          |          |

# ADVISORY BOARD CALENDAR

December 16, 2009

| Calendar #  | Submission # | Applicant Name and Address   | Type of Request  | Installation Location  | Status   | Fee      |
|---|--------------|--|--|--|----------|----------|
| 49878   | 09A0519      | S.J. Electric, Inc.<br>601 Union Street<br>Brooklyn NY 11215                                       | Requested approval for the electric service equipment proposed to be installed | Riverside South, Bldg. J1<br>60 Riverside Blvd.<br>New York NY | Approved | \$650.00 |
| 1) Fuse on normal side feeding "DP-HEM" oversized. (Svc. A). 2) Indicate wire size for emergency for supplying DP-HEM. (SVC A). 3) Verify wire size on load-side of ATS feeding DP-HEM (SVC A). 4) Show grounding of gen chasis(SVC A). 5) Indicate fire rated feeder for fire pump emergency side(SVC A). 6)Confirm man. fire pump does not require emergency feed(SVC A). 7) Show wire size on primary of 75KVA transformer(SVC A). 8) Provide reduced neutral calculation for FDR to DP-HC1(SVC B). 9) Feeder to retail trough undersized (SVC B). 10) Feeder to fut retail loads undersized. SWS drawn backward. 11) Switchboard room doors to open out. Job finalized 4/5/10 |              |  |  |  |          |          |
| 49879   | 09A0520      | Arc Electl & Mechanical Contrs, Corp.<br>26 Delavan Street<br>Brooklyn NY 11231                    | Requested approval for the electric service equipment proposed to be installed | Harlem Hospital<br>512 Lenox Avenue<br>New York NY             | Denied   | \$650.00 |
| 1) Service room to be mechanically ventilated. 2) Verify that there is not life safety equipmet and emergency feeders in the service room. 3) End box details not provided. 4) Secondary of transformers to be bonded and grounded. 5) Wiresizes not shown on load side of transformers. 6) Service switch are reversed on 1 line. &) Fire pump conductors not shown on drawing or fire rated. 8) Generator feeders are overfused. 9) Bus sizes for paralleling gear shown on drawing. 10) FCO feed to be fed from paralleling gear. 11) Print to small to read! 12) Emergency feeders not to be run through the service room unless fire rated.                                  |              |  |  |  |          |          |
| 49880   | 09A0521      | Empire City Electrc Inc.<br>68 East 131sr Street, Suite 302<br>New York NY 10037                   | Requested approval for the electric service equipment proposed to be installed | The Alexander<br>250 East 49th Street<br>New York NY           | Hold     | \$650.00 |
| 1) Show supplemental ground lug. 2) More than 6 service switches. 3) Service bus feeding 800, 600 & 200 amp switches is undersized. 4) Tap detail trough not shown. 5) Show how 4 sets of 500 MCM will terminate a 600 amp switch and main breaker on panel. 6) Annunciator system not shown.   |              |  |  |  |          |          |
| 49881   | 09A0522      | VMA Electrical Corp.<br>1652 77th Street<br>Brooklyn NY 11214                                      | Requested approval for the electric service equipment proposed to be installed | 365 Broadway<br>New York NY                                    | Approved | \$650.00 |
| 49882   | 09A0523      | Gallant Electrical Constuction, Inc..<br>260 Beach 116th Street, Suite 1<br>Rockaway Park NY 11694 | Requested approval for the electric service equipment proposed to be installed | 976 Third Avenue<br>Brooklyn NY                                | Denied   | \$650.00 |
| Submittal not in Advisory Board format.   |              |  |  |  |          |          |

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar #   | Submission # | Applicant Name and Address   | Type of Request   | Installation Location  | Status   | Fee      |
|--|--------------|--|---|--|----------|----------|
| 49883  | 09A0524      | Fas Electrical Contractors, Inc.<br>90-61 Pitkin Avenue<br>Ozone park NY 11417   | Requested approval for the electric service equipment proposed to be installed  | Van Blarcom Closures, Inc.<br>156 Stanford Street<br>Brooklyn NY | Hold     | \$650.00 |
| 1) Neutral in 2000 amp service switch not bonded to enclosure. 2) Fire pump branch circuit to be fire rated. 3) Group lug on load side of neutral link. 4) Fire pump service switch to be separated 12" from other service switch. 5) Drawing is too light to read.  |              |  |   |  |          |          |
| 49884  | 09A0510      | Welsbach Electric Corp.<br>111-01 14th Avenue<br>College Point NY 11356          | Requested approval for the electric service equipment proposed to be installed  | South Brooklyn Marine Term.<br>39th Street<br>Brooklyn NY        | Approved | \$650.00 |
| 1) Confirm sync check protection is incorporated in 15KV switchgear. 2) Confirm short circuit study reflects contribution from(4) 7500KVA transformers (3 new, 1 fut). Verify adequate rating of 15KV switchgear. 3) Provide justification/load flow analysis for sizing of main bus in 15KV switchgear. Job finalized 3/8/10. |              |  |   |  |          |          |
| 49885  |              | Allran Electric of New York<br>120 Broadway, 38th Floor<br>New York NY 10271     | Requesting permission to utilize existing service bus where the neutral bus is undersized and load calculations are provided.   | Milford Plaza Hotel<br>700 8th Avenue<br>New York NY             | Approved | \$0.00   |
| 49886  |              | Litespeed Electric, Inc.<br>135 West 29th Street, Suite 301<br>New York NY 10001 | Requesting permission to replace the interior of a 5000 amp service switch with new without filing Advisory Board drawings where first and second fusing will be coordinated. | 230 Park Avenue<br>New York NY                                   | Approved | \$0.00   |
| With the stipulation that the new 5000 amp switch can not contain fuses rated more than 4000 amps and permanent signage shall be affixed to t the switch indicating so.  |              |  |   |  |          |          |
| 49887  |              | Fried Electric Co. Inc.<br>72 Orchard Street<br>New York NY 10002                | Requesting permission to install a new 200 amp service switch to an existing 1000 KVA service without filing Advisory Board drawings.   | 58-30 Grand Avenue<br>Maspeth NY                                 | Denied   | \$0.00   |

# ADVISORY BOARD CALENDAR

**December 16, 2009**

| Calendar # | Submission # | Applicant Name and Address   | Type of Request  | Installation Location  | Status   | Fee      |
|------------|--------------|--|--|--|----------|----------|
| 49888      |              | altPower, Inc.<br>125 Maiden Lane, Suite 307<br>New York NY 10038                          | Requesting permission due to added expense to allow the installation of a 6.65 KW photovoltaic system without the testing requirement of 690.1 due to the installation being performed for a non profit organization by a licensed electrician | 1323 Louis Nine Blvd.<br>Bronx NY                                    | Hold     | \$0.00   |
| 49889      |              | AL-BA Electrical Corp.<br>3521 Avenue S<br>Brooklyn NY 11234                               | Requesting permission to install AC cable that does not contain an insulated equipment grounding conductor to be used as a wiring method in a place of assembly  | 243 West 54th Street<br>New York NY                                  | Approved | \$0.00   |
| 49890      |              | Atkinson Koven Feinberg Engineers<br>330 West 42nd Street, 14th Floor<br>New York NY 10036 | Requesting permission on a installation where the fire pump controller , and branch circuit wiring will be replaced to allow a isolated fire pump service switch to be installed fused at 300% of the motors full load amps.                   | Weill Cornell Medical College<br>420 East 70th Street<br>New York NY | Approved | \$0.00   |
| 49891      | 09A0525      | Inscape Corp.<br>67 Toll Road<br>Holland Landing ON L9N1H                                  | Requested approval for use in New York City of your Tisch Office Furnishings with electrical system power infeed. Model/Series numbers: BTFWK-NY.  |  | Approved | \$200.00 |
| 49892      | 09A0526      | Jones Group<br>305 Lost Creek Drive NW<br>Atlanta GA 30152                                 | Requested Concept Approval:  | 1285 Avenue of the Americas<br>New York NY                           | Approved | \$0.00   |