

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 129-03-E
Report of Materials and Equipment Acceptance Division

Manufacturer – Goodman Manufacturing, 2550 North Loop West, Suite 400, Houston, TX 77092.

Trade Name(s) – Goodman, Amana, Janitrol, GMC.

Product – Self-contained air conditioning units.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Tests – RS 13-11 (UL1995).

Laboratory – Underwriters Laboratories, Inc.

Test Report – UL File SA10054, dated June 25, 1997, revised August 19, 1998.

Description – Self-contained air conditioning units, designed for outdoor installation.

R-22 is the refrigerant used for the system. Units consists of hermetic sealed compressor, air cooled condenser with fan and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity (BTUH)
PPC24*02*	24,000
PC024-1*	24,000
PHD24*02*	24,000
PHB24*02*	24,000
PPC30*02*	30,000
PC030-1*	30,000
PHB30*02*	30,000
PHD30*02*	30,000
PPC36*02*	36,000
PC036-1*	36,000
PC036-3*	36,000
PHB36*02*	36,000
PHD36*02*	36,000
PCC42*02*	42,000
PC042-1*	42,000
PC042-3*	42,000
PHB42*02*	42,000
PHD42*02*	42,000

PCC48*02*	48,000
PC048*02*	48,000
PHB48*02*	48,000
PHD48*02*	48,000
PCA60*02*	60,000
PCC60*02*	60,000
PHB60*02*	60,000

* May contain alpha character (A-Z)

Recommendation - That the above described self-contained air conditioning units be accepted for outdoor installation, when utilizing refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with provisions Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 6/25/03
Examined by Shymon Provan