



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 13-92-E Vol. 27

Manufacturer: GE Security Inc., 8985 Town Center Parkway, Bradenton, FL 34202

Trade Name(s): EST, Mirtone, ADT

Product: Various control panel components, fiber optics modules and remote annunciators

Pertinent Code Section(s): 27-968 thru 27-977, Subchapter 17 and Reference Standards RS17-3, RS17-3A, RS17-3B & RS17-3C

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc

Test Report(s):

1. UL File S3000, Projects 01NK05159 & 01NK40698, issued August 22, 2001, revised March 3, 2006.
2. UL File S3424, Project 00NK48953, issued June 29, 2001, revised September 10, 2004.
3. UL File S3424, Project 97NK42263, issued May 18, 1998.
4. Multiple Listing File No. S6230, issued February 13, 2004, revised December 6, 2004.
5. Multiple Listing File No. S232, issued April 23, 1986, revised October 28, 2004.

Description: Various modules for our EST3 and QuickStart panels.

Products Covered

EST Cat. No.	Description	UL File Number
EST-SRA1	Remote annunciator for QuickStart	S3424, Vol. 15, Sec. 1
EST-SRA4	Remote annunciator for QuickStart	S3424, Vol. 15, Sec. 1
XGD	Graphic annunciator driver card	S3424, Vol. 10, Sec. 1

Mirtone Cat. No.	Description	UL File Number
MIR-SRA1	Remote annunciator for QuickStart	ML file S6230
MIR-SRA4	Remote annunciator for QuickStart	ML file S6230

ADT Cat. No.	Description	UL File Number
ADT-SRA1	Remote annunciator for QuickStart	ML file S232
ADT-SRA4	Remote annunciator for QuickStart	ML file S232

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated December 27, 2006, F.P. Index #061027.

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3.
2. Installation shall be in accordance with the manufacturer's recommendations, NFPA 72 and UL standard.
3. Control functions of the fire alarm system shall not be permitted in these annunciators except the alarm-knowledge function.
4. The above product shall be used only with approved/accepted and compatible control panels and accessories.
5. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 23, 2007
Examined By Donald [Signature]