

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Richard C. Visconti, R.A., Acting Commissioner
MEA 132-00-E**

Report of Material and Equipment Acceptance Division

**Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue,
St. Charles, IL. 60174**

Trade Name(s) - Johnson Controls, Notifier.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268.

Laboratory - Underwriters Laboratories, Inc.

**Test Report(s) - UL File S2101, Volume 2, Section 2, issued June 1, 1999 and ML File S2375,
Issued March 13, 1989 and revised November 15, 1999.**

Description - Multiple listing for System Sensor's smoke detector as follows:

Product Covered	Vol.	Basic Applicant's (Supplier) Notifier Pittway Co. System Sensor, Product Designation	Multiple Listee's Johnson Control Instruments Inc. Product Designation
Fire detectors	33	FST-751 FST-751R	5351J 5351RJ

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated January 10, 2000, F.P. Index #0001009 for equivalent model number under MEA 278-99-E approved May 18, 2000.

Recommendation - That the above detectors be accepted on conditions that all configurations, arrangements and functions, applications and installations comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3 and the UL listing. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance *October 24, 2000*
Examined By *Mark Jack*