



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 14-06-E

**Manufacturer:** Goodman Manufacturing, 2550 North Loop West, Houston, TX 77092.

**Trade Name(s):** Goodman, Amana, Janitrol, GMC.

**Product:** Air cooled condensing unit.

**Pertinent Code Section(s):** 27-770, 27-777.

**Prescribed Test(s):** RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

**Laboratory:** Intertek Testing Laboratories

**Test Report(s):** No. 3083-366-002, dated February 2, 2006.

**Description** – Split system air cooled condensing units, designed for outdoor installation. R-22 is the refrigerant used for the system. Units consist of air cooled condenser, direct driven centrifugal fan, hermetic type compressor and controls. Manually reset type pressure limiting device is provided with setting at 400 psi, maximum. Units, with model numbers and cooling capacities, are listed below.

<b>Model No.</b>	<b>Tons</b>
<b>GSC130181**</b>	<b>1.5</b>
<b>GSC130241**</b>	<b>2</b>
<b>GSC130301**</b>	<b>2.5</b>
<b>GSC130361**</b>	<b>3</b>
<b>GSC130363**</b>	<b>3</b>
<b>GSC130421**</b>	<b>3.5</b>
<b>GSC130481**</b>	<b>4</b>
<b>GSC130483**</b>	<b>4</b>
<b>GSC130484**</b>	<b>4</b>
<b>GSC130601**</b>	<b>5</b>
<b>GSC130603**</b>	<b>5</b>
<b>GSC130604**</b>	<b>5</b>
<b>GSC140181**</b>	<b>1.5</b>
<b>GSC140241**</b>	<b>2</b>
<b>GSC140301**`</b>	<b>2.5</b>
<b>GSC140361**</b>	<b>3</b>
<b>GSC140421**</b>	<b>3.5</b>
<b>GSC140481**</b>	<b>4</b>
<b>GSC140601**</b>	<b>5</b>
<b>ASC130181**</b>	<b>1.5</b>
<b>ASC130241**</b>	<b>2</b>
<b>ASC130301**</b>	<b>2.5</b>
<b>ASC130361**</b>	<b>3</b>
<b>ASC130421**</b>	<b>3.5</b>
<b>ASC130481**</b>	<b>4</b>
<b>ASC130601**</b>	<b>5</b>
<b>SSX140181**</b>	<b>1.5</b>
<b>SSX140241**</b>	<b>2</b>
<b>SSX140301**</b>	<b>2.5</b>
<b>SSX140361**</b>	<b>3</b>
<b>SSX140421**</b>	<b>3.5</b>
<b>SSX140481**</b>	<b>4</b>
<b>SSX140601**</b>	<b>5</b>
<b>SSX160241**</b>	<b>2</b>
<b>SSX160361**</b>	<b>3</b>
<b>SSX160481**</b>	<b>4</b>
<b>SSX160601**</b>	<b>5</b>

Model No.	Tons
ASX140181**	1.5
ASX140241**	2
ASX140301**	2.5
ASX140361**	3
ASX140421**	3.5
ASX140481**	4
ASX140601**	5
ASX160241**	2
ASX160361**	3
ASX160481**	4
ASX160601**	5

**Terms and Conditions:** The above described air-cooled condensing units are accepted for outdoor installation, when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/24/06

Examined by Shyam. Prasad

