



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 142-08-M

Manufacturer: Simpson Dura-Vent, 902 Aldridge Road, Vacaville, CA 95688

Trade Name(s): DuraChimney II

Product: All fuel chimney, residential type and building heating appliance
MEA Index #130-10 – Dual & Triple Walled Chimneys

Pertinent Code Section(s): 27-855

Prescribed Test(s): RS 15-8[A] (UL 103)

Laboratory: Underwriters Laboratories Inc.

Test Report(s): UL File MH7399 dated October 10, 2007.

Description: Factory-built chimneys, model DuraChimney II air-cooled 10” thru 16” diameters, are residential type and for building heating appliances. The chimney consists of an inner stainless steel casing (flue gas conduit) with an outer stainless for CNL labeled chimneys, stainless steel or galvanized steel casing for USL labeled chimneys. The annular space between the inner and outer casings is insulated. The chimney is for single and multi-story buildings or masonry fireplaces in the vertical orientation only. The minimum installation clearance is 2 inches to enclosure walls and roof structure and as determined by specified factory-furnished parts at floors, joists, roof and ceiling. Maximum chimney heights for the various support methods are as follows:

Ceiling Support: 61 ft.

Roof Support: 35 ft. 7 in. diameter; 50 ft 5 in. diameter and 6 in. diameter

Product Covered:

DuraChimney II – residential-type and for building heating appliance.

Terms and Conditions: The above-described factory-built chimneys, residential type and for building heating appliances, are accepted with the following conditions:

1. Chimneys shall be used where allowed by New York City Building Code as Listed Factory-built chimneys intended for the venting of wood-burning, liquid or gas fuel exhaust gases at a temperature not exceeding that recommended by the manufacturer under continuous operating conditions.
2. Chimneys shall not be used with Factory-built fireplaces unless specifically referenced in the laboratory listing of the fireplace units.
3. Chimneys shall be installed in accordance with installation instructions provided by the manufacturer and in accordance with the Building Code for Listed Factory-built chimneys.
4. Chimneys shall be enclosed in accordance with the Building Code.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 26, 2008
Examined By Donald [Signature]