

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 143-00-E Vol. II

Report of Material and Equipment Acceptance Division

Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) - Notifier (& System Sensor), A Division of Pittway, Johnson Controls, Inc.

Product - Fire Alarm Equipment - Smoke Duct Detector.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268A.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 99NK38889, dated issued March 24, 2000 (MEA 143-00-E). UL Files S911, Project 99NK38889, issued March 24, 2000 and revised August 24, 2000 and UL letter dated October 4, 2000. ML File No. S19848 issued March 9, 1994 and revised September 25, 2000 (MEA 389-00-E).

Description - Smoke Duct Detectors are multiple listed as follows:

Basic Applicant's Designation	Multiple Listee	MEA No.	Date
Notifier, A Division of Pittway	Johnson Controls, Inc.		
FSD-751P	DH300P	143-00-E	2/7/2001
FSD-751RP	DH300RP	389-00-E	10/30/2000

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated October 18, 2000, F.P. Index No. 0010023 (MEA 389-00-E) and Bureau of Fire Prevention letter dated January 24, 2001, F.P. Index No. 0101007 (MEA 143-00-E).

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements, functions, applications and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3, 17-11, and 17-12. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, UL listing and the UL Standard. Models FSD-751P and FSD-751RP duct detectors shall be used only with listed and approved control panels with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 29, 2001

Examined By [Signature]