



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 15-08-E

Manufacturer: HearthStone Quality Home Heating Products
317 Stafford Avenue, Morrisville, VT 05680

Trade Name(s): HearthStone

Product: Factory-built wood-burning room heating appliance
MEA Index 300-10 – Factory-built Fireplace

Pertinent Code Section(s): Subchapter 14, Article 19

Prescribed Test(s): RS 14-21 (UL 1482)

Laboratory: Intertek Testing Services

Test Report(s): Report No. 3109396-T1 issued May 23, 2007.

Description: Wood-fired room heater, Model 8170, with rating of 35,000 Btu/hr. Unit is a double-walled steel construction with soapstone panels and EPA rated at 3.57 g/hr – 1.25 cubic inches firebox volume.

Stove Dimensions:- Height – 41½”; Diameter – 19½”

Terms and Conditions: The above-described factory-built fireplaces are accepted for use as supplemental heating and decorative purposes.

- 1. Installation shall be in accordance with manufacturer’s supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 5, 2008
Examined By Donald Hill