



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 160-08-E

**Manufacturer:** Canplas Industries Ltd.  
500 Veterans Drive  
Barrie, ON L4N 9J5

**Trade Name(s):** Canplas® Endura®

**Product:** Grease Interceptors (Hydromechanical)  
MEA Index #400-10 – Grease Traps

**Pertinent Code Section(s):** RS 16 – P105.4 (d) (4)

**Prescribed Test(s):** ASME A112.14.3-2000 & PDI-G101

**Laboratory:** Industrial Testing Laboratories Inc.

**Test Report(s):** S500493 – issued February 2, 2006; S500548 – issued March 24, 2006; S301321 – issued February 21, 2006; S301322 – issued February 21, 2006; S401266 – issued February 21, 2006

**Description:** Injection-molded grease interceptors with quick release cover latches, non skid, load rated cover and removable baffles. Suitable for in-floor, on-floor installation or semi-recessed applications. Approved for installation using an external flow control device (supplied by manufacturer).

Model No.	Flow Rating (US GPM)	Grease Capacity (lbs)
3915A	15	30
3920A	20	40
3925A	25	50
3935A	35	70
3950A	50	100

**Terms and Conditions:** The above kitchen grease interceptors are accepted on condition that:

1. All uses, locations and installations comply with the New York City Building Code Subchapter 16 and Reference Standard RS-16, specifically Section P105.4 (d) (4) and the requirements of the Department of Environmental Protection.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 10, 2008  
Examined by Donald [Signature]