



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 165-05-E

Manufacturer: Roaster Tech, 13 Highland Drive, Ardsley, NY 10502.

Trade Name(s): Hibachi Table.

Product: Gas fired grills.

Pertinent Code Section(s): 27-800, 27-826, RS 14-2 (ANSI Z 223.1).

Prescribed Test(s): RS 14-6 (ANSI Z21.11).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File MH 27967, dated November 9, 2001.

Description – Units comprise main burners, pilot burners, safety shutoff devices, thermostats and pressure regulators. It is either manually controlled or thermostat controlled. Units, with ratings are listed below:

Model No.	Input Rating Btu/Hr.
TGU-08	38,000
TGU-10	38,000

Terms and Conditions: That the above commercial gas grills, be accepted, when fired by natural gas only, under the following conditions:

1. Unit shall be installed in accordance the manufacturer's instructions, National Gas Code and New York City Building Code requirements.
2. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS 13 requirements of the New York City Building Code and have a fire suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The Fire Suppression System exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.
3. For grease removal, suitable baffle type grease filters, MEA accepted, shall be installed in the exhaust duct.
4. Gas line tubing and fitting connectors shall permit flexibility for operation, cleaning and servicing and shall be MEA accepted for such use.
5. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber-installing unit.
6. All work provided by the installer from the point of gas utility company in line service termination to the equipment shall be subject to approval by the plumbing inspector,
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
8. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance September 29, 2005
Examined by Shyam Prasad SD