



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 168-93-E Vol. 7

Manufacturer: Digital Monitoring Products, Inc., 2500 N Partnership Blvd., Springfield, MO 65803

Trade Name(s): Digital Monitoring Products

Product: Fire alarm control units

Pertinent Code Section(s): Subchapter 17 and Reference Standard 17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S3598, Project 03NK20681, issued January 29, 2004, revised March 21, 2006

Description: Fire alarm control units.

Model Nos.	Description
XR100, XR100N	Signal System Control Units

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 23, 2007, F.P. Index #0701020.

Terms and Conditions: The above units are accepted on the following conditions:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building code, specifically subchapter 17, and with Reference Standard 17-3.
2. The installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard.
3. These fire alarm panels, when used with a central office communicator or a transmitter, the installation and operation of the equipment and devices shall comply with 3RCNY §17-01. The installation shall employ the digital dialer as the primary communicator. **Network IP communication may be used only as a backup or secondary means of communication.** It shall have the capability of transmitting separate and distinct signals to indicate manual pull-station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
4. The connection of security burglar devices and equipment to a fire alarm panel is prohibited. A sign must be provided to indicate same.
5. Installation of pre-recorded evacuation messages in the fire alarm control panel would require a prior approval from the Department.
6. The above-reference products shall be used only with listed and approved fire alarm equipments and accessories with which the compatibility has been determined by the Engineer of Record or a UL-test report.
7. The above panels are not configured to be installed as a fire command station.
8. All enclosing cases for above panels shall be painted red in color.
9. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 29, 2007.

Examined By

Donald [Signature]