



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 17-05-E Vol. 3

Manufacturer: Suburban Manufacturing Company, Inc.
676 Broadway Street, Dayton, TN 37321

Trade Name(s): Dynaline

Product: Combination direct vent gas-fired wall-furnace and electric air conditioning

Pertinent Code Section(s): 27-800, 27-825, 27-886, RS 14-2(ANSI 223.1)

Prescribed Test(s): RS 14-6 (ANSI Z21.86), RS 13-12 (UL484)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL file SA10773, dated July 19, 2002

Description: Combination direct-vent gas-fired wall furnace and electric air-conditioning unit, **model DL3**, designed for indoor installation. Heating section operates on natural gas and cooling section utilizes refrigerant R-22. Heating section is comprised of a direct drive combustion air blower assembly, a direct drive circulating air blower assembly, aluminized steel main burners, an interrupted ignition system consisting of ignition module, igniter and flame sensor and combination gas pressure regulator. Units are provided with a temperature limit control with setting at 220 degrees F, maximum. Cooling section is comprised of a compressor, condenser, capillary tubing and evaporator coil with fan. Units with model number and input heating ratings are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity, (Btu/hr)	Mfr.'s specified Nominal Heating Capacity, (Btu/hr)
DL3-0712	7,000	12,000
DL3-0912	9,000	12,000
DL3-1220	12,000	20,000
DL3-1622	16,000	22,000

Terms and Conditions: The above-described combination direct-vent, gas-fired wall furnace and electric air conditioning units are accepted for through-the-wall installation only, with the following conditions:

1. Units shall be fired by natural gas only with the fire rate as indicated, and utilize Refrigerant R-22.
2. Furnace shall be installed by a licensed plumber only, who shall insure that the installation is provided with unobstructed vent opening and that all the Gas Company's requirements for this type of installation are strictly enforced.
3. The flue tube cannot extend past the wall sleeve.
4. Units are suitable for use at 0" clearance from combustible materials. Units cannot be installed behind doors, in alcoves, or in an existing window opening.
5. Gas pressure regulator shall be installed and gas inlet pressure shall be adjusted by the installer to give inlet pressure at the burner orifice recommended by the manufacturer.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. All shipments and deliveries of such equipment shall have a tag affixed to the units and suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.
8. Units shall be installed in accordance with the Energy Conservation Construction Code of New York State.

NOTE: In accordance with Section 27-131 (d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 2, 2008

Examined By Sun Derk Hudson