

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

MEA 180-00-E
Report of Material and Equipment Acceptance Division

Manufacturer– TPI Corporation, 135 Wesley Street, P.O. Box T, Johnson City, Tennessee 37602.

Trade Name – Raywall, TPI Corporation, MARKEL.

Product – Electrical wall heaters.

Pertinent Code Section(s) – 27-787, 27-792.

Prescribed Tests– RS 14-6(ANSI Z2021).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File E25567, dated March 31, 2000.

Description – Fixed location air heaters, wall or ceiling. Cat. No. E followed by 303, 304 or 305 followed by 5 or 8, may or may not be followed by additional suffixes. Cat. NO. F, H or G, followed by 303, 304 or 305, followed by 2, may or may not be followed by additional suffixes. Cat. No. CRH, CPQ, or CFA, followed by 1, followed by 15 or 18, may or may not be followed by additional suffixes. Cat. No. CRH, CPQ or CFA, followed by 8, 2 or 7, followed by 20, may or may not be followed by additional suffixes. The heaters are convection heaters intended for use indoors. The heater is designed to be permanently connected to the power supply and is provided with finned resistance heating elements, regulating thermostat, manual-reset limit control and disconnect switch.

MODEL NUMBERS AND ELECTRICAL RATING:

Model Number	Voltage, V	Wattage, W	Current, I
E3035 or CRH115	120	1500/750	12.5/6.25
E3038 or CRH118	120	1800	15
E3045 or CPQ115	120	1500/750	12.5/6.25
E3048 or CPQ118	120	1800	15
E3055 or CFA115	120	1500/750	12.5/6.25
E3058 or CFA118	120	1800	15
F3032 or CRH820	208	2000	9.6
F30322 or CRH822	208	2250	10.8

Model Number	Voltage, V	Wattage, W	Current, I
F3042 or CPQ820	208	2000	9.6
F30422 or CPQ822	208	2250	10.8
F3052 or CFA820	208	2000	9.6
F30522 or CFA822	208	2250	10.8
H3032 or CRH220	240/208	2000/1500	8.33/7.2
H30322 or CRH222	240	2250	9.38
H3042 or CPQ220	240/208	2000/1500	8.33/7.2
H30422 or CPQ222	240	2250	9.38
H3052 or CFA220	240/208	2000/1500	8.33/7.2
H30522 or CFA222	240	2250	9.38
G3032 or CRH720	277	2000	7.22
G3042 or CPQ720	277	2000	7.22
G3052 or CFA720	277	2000	7.22

Recommendation - That the above described electric heaters be accepted when installed over noncombustible substrate in accordance with manufacturer's installation instructions and under the following conditions:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

JUN 28 2000

Final Acceptance _____

Examined By S. Derphudam