

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 201-00-E

Report of Material and Equipment Acceptance Division
Manufacturer - System Sensor, A Division of Pittway, 3825 Stern Avenue,
St. Charles, IL. 60174

Trade Name(s) - Fire-Lite Alarms Inc.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 00NK11469, Volume 53, Section 1, Issued April 25, 2000 and UL letter dated May 23, 2000.

Description - Fire-Lite's Photoelectric Battery operated smoke detector with integral heat detector and RF transmitter.

Model Number	Description
SDRF-351	6 VDC Photoelectric Battery Operated Smoke Detector without audible alarm signal
SDRF-351S	6 VDC Photoelectric Battery Operated Smoke Detector with audible alarm signal

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated July 1, 2000, F.P. Index No. 0006021.

Recommendation - That the above smoke detectors with radio frequency transmitters be accepted on conditions that all uses, configurations, arrangements, functions, applications, and installations comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-11 & 17-12. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and the UL Standard. The models SDRF-351S and SDRF-351 shall be used with listed and approved control panels with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 3, 2000

Examined By Mark Feely