



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 205-94-E Vol. 8

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc.

Trade Name(s): System Sensor

Product: Fire Alarm Equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR), Subchapter 17.

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories Inc.

Test Report(s): S911 Project No#: 05NK21031, issued on March 17, 2003, revised on July 12, 2005.

Description – Smoke detector, conventional type with supplementary heat detector.

Model Number- 2151T

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objection letter dated April 4, 2006, F.P. Index No# 0603066.

Terms and Conditions: That the above units be accepted on condition that:

1. All uses, configurations, arrangements, functions, applications, and installation shall comply with the provision of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing of detectors shall be in accordance with the manufacturer's recommendations, NFPA 72 and UL standard 268.
2. The above product shall be used only with approved/accepted and compatible control panels and accessories.
3. Periodic maintenance and sensitivity test shall be conducted in accordance with the regulations of the Fire Department.
4. UL and manufacturer's maintenance procedures and limitations shall be complied with.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance May 4, 2006.
Examined by Donald J. [Signature]