



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 208-06-E

Manufacturer: International Comfort Products, 7310 W. Morris Street, Indianapolis, IN 46231

Trade Name(s): Heil, Comfortmaker, Airstart, Arcoaire, ICP Commercial, KeepRight, Tempstar, Kenmore

Product: Air-cooled condensing units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-8 (UL 303, UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL file SA11583, dated November 7, 2005.

Description: Self-contained 13 SEER air-cooled condensing units, designed for outdoor installation. R-22 is the refrigerant used for the system. Unit is comprised of sealed compressor, air-cooled condenser with fan and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model Number	Mfr's Specified Nominal Cooling Capacity, Tons
(C, H, T) 2A318**A	1.5
(C, H, T) 2A324**A	2
(C, H, T) 2A330**A	2.5
(C, H, T) 2A336**A	3
(C, H, T) 2A342**A	3.5
(C, H, T) 2A348**A	4
(C, H, T) 2A360**A	5

- C, H, or T depending on the brand of Comfortmaker, Heil, or Tempstar
- * A= Standard Grill, G= Coastal Grill
- * H= 208/230 three phase, K= 280/230 single phase, L= 460 three phase

Terms and Conditions: The above-described air-cooled condensing units are accepted under the following conditions:

1. Units shall be installed outdoors.
2. Units shall use only Refrigerant R-22.
3. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 3, 2007

Examined By Simon Derkshdam