



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 210-82-M Vol. 2

Manufacturer: Thermafiber, Inc.
3711 Mill Street
Wabash, IN 46992

Trade Name(s): Thermafiber Mineral Felt Insulation

Product: Mineral-fiber thermal insulation material

Pertinent Code Section(s): 27-232, 27-335.1

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Underwriters Laboratories, Inc.
United States Testing Company, Inc.

Test Report(s): UL File R4643, dated January 22, 1969, October 8, 1970, August 31, 1971, May 26, 1977 and February 16, 1983.
U.S. Testing: No. 4037 dated July 30, 1982.

Description: Semi-rigid thermal curtain wall insulation blanket material, manufactured from mineral fibers with suitable binders, in 1-inch, 2-inch, 2½-inch and 3-inch thickness and nominal 8.0 pounds per cubic foot density.

Flame Spread Rating – unfaced	0 (max.)
Flame Spread Rating – faced:	25 (max.)
Smoke Developed Rating:	0 (max.)

Terms and Conditions: The above-described mineral-fiber thermal insulation material is accepted under the following conditions:

1. The material may be used in either new or existing combustible or non-combustible construction.
2. This acceptance shall not be construed to provide a fire-resistance rating or an assembly comprising the insulation, in which entire assembly shall be required to be tested under ASTM E119 to determine the fire-resistance rating.
3. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance January 16, 2008

Examined By: Sivan Derphudem