

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner  
MEA 215-00-M

Report of Material and Equipment Acceptance Division

Manufacturer - Tokiwa Industries, LTD. 1-2-17, Minamihiraki, Nishinari-ku, Osaka, Japan.

Trade Name - Genre.

Product - Wallcovering material.

Pertinent Code Section(s) - 27-348.

Prescribed Test(s) - RS 5-5 (ASTM E84), Toxicity.

Laboratory - SGS US Testing Company, Inc and Southwest Research Institute.

Test Report(s) - U.S. Report No. 132166-1 dated October 26, 1999 and SwRI project No. 01.03051.01.031 dated March 22, 2000.

Description - Genre Wallcovering material, Whispering Leaves GE2241 is vinyl on paper with woven backing. Total weight is 13.7 oz/sq.yd and vinyl weight is 9.4 oz/sq.yd and backing weight is 4.3 oz/sq.yd.

Flame Spread Rating - 15. Smoke Density - 30.

Recommendation - That the above described wallcovering material be accepted for interior finish Class A with flame spread rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such materials shall, be accompanied by a metal tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance JUL 27 2000

Examined By Simon Verkhudam