



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 215-06-M

Manufacturer: Performance Roof Systems Inc., 4800 Blue Parkway, Kansas City, MO 64130

Trade Name(s): Derbigum/Derbicolor/DerbiBrite/Bitutak/RPS190

Product: Roofing material

Pertinent Code Section(s): 27-337

Prescribed Test(s): RS 5-10 (ASTM E108)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File R13327 dated January 12, 1993, August 24, 1994, November 14, 2003 and July 2, 2004.

Description: Derbigum roofing systems utilizing Derbigum (GP, GP-FR), Derbicolor (GP, GP-FR), Derbigum (XPS, XPS-FR), Derbicolor (XPS, XPS-FR), DerBrite, Bitutak, Bitutak Mineral, PRS190 and PRs190 Mineral can be installed as described below when following manufacturer's installation instructions, and in accordance with Underwriters Laboratories, Inc. UL File R13327 for the following system.

Terms and Conditions: The above-described roofing covering assemblies are accepted under the following conditions:

1. Roofing shall be installed in accordance with roof inclines specified for Class A, B or C fire-resistance classifications when used on specified decks with the specified maximum slope following manufacturer installation instructions, and in accordance with the Underwriters Laboratories File R13327 for the system.
2. All shipments and deliveries of such materials shall be provided with a label or tag tag, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance October 9, 2007

Examined By Simon Derkhuizen