

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, A.I.A., Commissioner
MEA 219-02-E Vol. IV
Report of Material and Equipment Acceptance Division**

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) –Secutron, System Sensor.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – Reference Standard RS 17-3, RS 4-6 (886-89-BCR).

Test(s) – UL 268.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL 268 File 911, Project 93NK8813, Volume 23, issued October 11, 1993, revised June 11, 2002, and UL letter dated June 26, 2002. ML file No. S6487, issued December 10, 1998 and revised August 19, 2002.

Description –Secutron Photoelectric Smoke Detectors are multiple listed as follows:

System Sensor, Division of Pittway Corp. Basic Applicant's (Supplier's) Product/Module Designation	Secutron, Div. Of Digital Security Controls, Ltd. Multiple Listee's Product/Module Designation
2251B	MRI-2251B
2251TB	MRI-2251TB
2251TMB	MRI-2251TMB

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention had no objections to equivalent model numbers letter dated July 29, 2002, F.P. Index 020705 under MEA 219-02-E.

Recommendation - That the above smoke detectors be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3 and the UL Listing. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department. These units shall be used with a compatible UL Listed and MEA approved fire control panels. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance FEBRUARY 28, 2003
Examined by 