

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found for use in accordance with the report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA225-05-M Report of Material and equipment
Acceptance Division

Manufacturer- USG Interiors, Inc. 125 S. Franklin Street, Chicago, IL. 60606-4678.
Tradename - AURATONE Product Line, Aspen, Fissured, Radar, Radar Illusion, Radar ClimaPlus, Radar ClimaPlus Illusion, Radar ClimaPlus High CAC, High NRC, Radar Ceramic ClimaPlus, Rockface ClimaPlus, Touchstone ClimaPlus, Saville Row, Fifth Ave., Superpanel.

Product-Acoustical Ceiling Panels and Tiles.

Pertinent Code Sections - 27-348.

Prescribed Tests - RS 5-5, (ASTM E84), Toxicity.

Laboratory- Underwriters Laboratories Inc., Southwest Research Institute,

Test Reports - Southwest Research Institute report 01.11020, UL Letter report R3623 04NK27471 dated 1-4-1995, UL letter report R3623 98NK26629 dated 8-17-1998, UL letter report R3623 99NK42556 dated 1-13-2000.

Description - The acoustical ceiling panels and tiles listed under "Trade Name" above, are offered in thicknesses of 5/8 inch to 1 inch. The length and width dimensions range in size from 24 inch x 24 inch to 24 inch x 48 inch. These acoustical ceiling panels and tiles are designed for use in exposed and concealed grid installations and are offered in edge configurations - Square (SQ), Shadowline Tapered (SLT) and Fineline Beveled (FLB).

Flame Spread Rating - 25

Smoke Developed Rating - 50

Recommendation - That the above described acoustical ceiling products be accepted for interior use finish, with Class A flame spread rating and smoke developed rating listed above. Upon exposure to fire, the acoustical panels did not produce products of decomposition that were more toxic than wood when decomposing or burning under comparable conditions.

All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July/28/05

Examined By S Derkudam