



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 226-04-E

Manufacturer: CFM Majestic Inc., 475 Admiral Boulevard, Mississauga, Ontario L5T 2A3, CANADA

Trade Name(s): Vermont Castings Majestic

Product: Gas-fired, vented, decorative fireplace appliance

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z21.88a)

Laboratory: CSA International

Test Report(s): No. 1646050 dated June 27, 1995

Description: Gas-fired, decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Model	Gas Input (BTUH)
33X DVR (RN, RFN, ENTN)	21,500
333XDV (RN, RFN, ENTN)	21,500 Unit Opt. Fan
36XDV (RN, RFN, ENTN)	27,500
34XDV (RN, RFN, ENTN)	31,000

Terms and Conditions: The above-described gas-fired, vented appliances are accepted for decorative heating operation under the following conditions:

1. Units shall use natural gas only.
2. Units shall be installed indoors only, with combustible air and required ventilation air provided.
3. Venting of the above equipment is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance _____ 5/23/07 _____

Examined By _____ Ryan. [Signature] _____