

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code SECTION 27-131, the following equipment or material has been found for use in accordance with the report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 227-05-M Report of Material and equipment
Acceptance Division

Manufacturer- USG Interiors, Inc. 125 S. Franklin Street, Chicago, IL. 60606-4678.
Tradename - AURATONE Class A Product Line, Aspen, Fissured, Olympia Micro
ClimaPlus, Pebbled, Radar, Radar ClimaPlus, Radar Illusion, Radar
ClimaPlus Illusion, Alpine, Saville Row, Fifth Avenue, Majestic ClimaPlus,
Stonehurst, Sierra, Plateau, Adobe.

All products are classified by Underwriters as Type CSB and GSB for
Surface Burning Characteristics .

Product - Class A Acoustical Ceiling Panels and Tiles.

Pertinent Code Sections - 27-348.

Prescribed Tests - RS 5-5, (ASTM E84), Toxicity.

Laboratories - Underwriters Laboratories Inc., Southwest Research Institute.

Test Reports - Southwest Research Institute report 01.11020, UL letter report
R3623 94NK27471 dated 1-4-1995, UL letter report R3623 98NK26629 dated
8-17-1998, UL letter report R3623 99NK42556 dated 1-13-2000

Description - The acoustical ceiling panels and tiles listed under "Trade Name"
above , are offered in thicknesses of 9/16 inch to 1/2 inch. The length and
width dimensions range in size from 12 inch x 12 inch to 30 inch x 60 inch.
These acoustical ceiling panels and tiles are designed for use in exposed
and concealed grid installations and are offered in edge configurations -
Square (SQ), Shadowline Tapered (SLT), Fineline Beveled (FLB), Interline
Tapered (ILT), Staple Flange (SF) and Beveled Edge Standard Kerf (BESK).
Flame Spread Rating - 25 Smoke Developed Rating - 50

Recommendation - That the above described acoustical ceiling products be
accepted for interior use finish, with Class A flame spread rating and smoke
developed rating listed above. Upon exposure to fire, the acoustical panels
did not produce products of decomposition that were more toxic than wood
when decomposing or burning under comparable conditions.

All shipments and deliveries of such equipment shall be provided with a
laboratory label and a permanent tag, suitably placed, certifying that the
equipment shipped or delivered is equivalent to that tested and accepted for
use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

July 28/05

Examined By

S. Derkshidan