

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Ronny A. Livian, P.E., Acting Commissioner
MEA 229-00-E Vol. II

Report of Material and Equipment Acceptance Division
Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue
St. Charles, IL. 60174

Trade Name(s) - Notifier, Pittway Co., Johnson Controls Inc.

Product - Smoke automatic fire detectors.

Pertinent Code Section(s) - Reference Standard RS 17.

Test(s) - UL 268, UL 864, UL 521, UL 539.

Laboratory - Underwriters Laboratories, Inc.

Test Report - ML File No. S1948, issued December 7, 1998 and revised October 11, 2001.

Description - System Sensor, Division of Pittway smoke detectors are multiple listed with Johnson Controls Inc. as follows:

| Model No. | Previously approval under MEA No. | Multiple Listee Johnson Control Inc. Model No. | Description |
|-----------|-----------------------------------|--|--|
| FAPT-751 | 229-00-E | 2351TMJ | Photoelectric W/Heat detector |
| HPX-751 | 212-00-E | FTX-P2J | "HARSH" (Hostile Area Smoke Head) Photoelectric smoke detector |

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections to equivalent model numbers as follows: MEA 229-00-E, Model FAPT-751, F.P. letter dated May 23, 2001, F.P. Index #0006064A; MEA 212-00-E, Model HPX-751, F.P. letter dated July 25, 2000, F. P. Index # 0006026.

Recommendation - That the above smoke detectors be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. Periodic sensitivity testes where required shall be conducted in accordance with the regulations for the Fire Department. FAPT-751 and 2351TMJ shall be used only with listed and approved control panels with which the compatibility has been determined by a nationally recognized laboratory test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance *May 29, 2002*
Examined *Mark Jacoby*