



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 229-06-E

Manufacturer: AboveAir Technologies, LLC, 4844 Winchester Blvd., Frederick, Maryland 21703

Trade Name(s): VertiKul "VK"TM

Product: Air conditioner and heat pump units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11A (UL 1995)

Laboratory: Intertek Testing Services

Test Report(s): No. 3088974-002, dated March 29, 2006

Description: AboveAir VeriKul (VK) series direct expansion remote air, water, glycol-cooled condensers and condensing units. Units may or may not be configured for heat pump operation. Units have 1-30 tons cooling using at most 15 ton compressor circuits with R-22 or F-407C refrigerant.

Terms and Conditions: The above-described heating/cooling units are accepted under the following conditions:

1. Heating section must operate on natural gas and cooling section employs only Refrigerant R-22 or R-407C.
2. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closeable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.

3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 2/14/07

Examined By Shyam. R. J.