

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 24-00-E
Report of Material and Equipment Acceptance Division**

Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) – GS Building Systems Corp.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL268.

Laboratory - Underwriters Laboratories, Inc.

Test Report - UL ML File S853, Issued June 12, 1980 and revised November 12, 1999.

Description – GS Building Systems' smoke detector is multiple listed as follows:

Basically Listed for	Multiple Listee
System Sensor, Division of Pittway Corp.	GS Building Systems Corp.
2251T	2251TF

Photoelectric smoke detector with heat detector.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections letter dated December 30, 1999, F.P. Index No. 9912062 for equivalent model no. under MEA 205-94-E Vol. III.

Recommendation - That the above smoke detectors be accepted on condition that all uses shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3 and the UL Listing. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72, and the UL Standard. Periodic sensitivity tests where required shall be conducted in accordance with the regulation of the Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 19, 2001

Examined By Mark J. [Signature]