



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 240-07-E

Manufacturer: FPI Fireplace Products International Ltd., 6988
Venture Street, Delta, BC V4G 1H4, CANADA

Trade Name(s): Regency

Product: Solid-fuel fireplace insert

Pertinent Code Section(s): 27-848, 27-856

Prescribed Test(s): RS 14-21 (UL 1482))

Laboratory: Intertek Testing Services

Test Report(s): 632-3198, 3115069, dated June 19, 2007.

Description: A wood fuel fireplace insert constructed of sheet metal. The unit may be installed in masonry or listed factory-built fireplaces. The firebox is shrouded at the sides, top and rear by a sheet steel convection air chamber. A convection air blower is installed beneath the ash fender. The firebox is refractory lined at the hearth, sides and rear. The firebox front consists of an out-swinging cast-iron and glass-viewing fuel door. A refractory baffle extends forward from the firebox rear at the top. Fixed-open secondary combustion air enters the firebox through an orifice tube mounted horizontally beneath the baffle. Primary combustion air enters via a manually operated damper and is channeled to enter the firebox front as under-fire air and behind the top of the fuel door as an air wash. Combustion products exit the unit through a 6-inch-diameter flue collar mounted on the unit top. This unit has a removable flue-line adaptor.

Product Covered

Model I1200S - Wood Fuel Fireplace Insert

Terms and Conditions: The above-described factory-built fireplace is accepted for operation under the following conditions:

1. The installation of unit shall be in accordance with manufacturer supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Unit shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 10/4/07
Examined By Joyens - P