



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 248-05-E

**Manufacturer:** Gamewell, 12 Clintonville Road, Northford, CT 06472-1001.

**Trade Name(s):** Gamewell

**Product:** Fire Alarm Equipment.

**Pertinent Code Section(s):** 27-968 through 27-977, Reference Standard RS 17.

**Test(s):** UL 864.

**Laboratory:** Underwriters Laboratories Inc.

**Test Report(s):** Project 9NK22223 and 04ME11013 issued December 29, 1994, revised November 1, 2004. UL letter dated July 21, 2005.

**Description** – The GWUDACT is an alarm dialer that is compatible with the following Gamewell control panels: Identiflex 602- MEA 415-03-E; Identiflex 630/650 Series – MEA 132-95-E; Identiflex 610 Series – MEA 149-99-E.

Model No.	Description
GWUDACT	Alarm Dialer

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated August 25, 2005, Index No. 0507035.

**Terms and Conditions:** That the above unit is accepted on condition that:

All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. These products shall be used only with compatible, listed and approved control panels.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance January 9 2006  
Examined by Donald [Signature]