

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A, Commissioner
MEA 249-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – PyroChem, 1 Stanton Street, Marinette, WI 54143.

Trade Name – Heiser Logistics Inc. - Protex II.

Product – Chemical Extinguishing Units for Protection of Restaurant Cooking
Arrears.

Pertinent Code Sections – Reference Standard RS 17-3, 13-3, NFPA 72.

Test(s) - UL 300, NFPA 17A, UL 1254.

Laboratory – Underwriters Laboratories, Inc.

Test Report(s) - Multiple Listing file No. Ex4521 issued September 10, 1993 revised
April 12, 2002.

Description – Chemical Extinguishing Units:

Heiser Model No.	Pyro-Chem Model No.	Description
L3000	PCL-300	Restaurant Fire Suppression System
L4600	PCL-460	Restaurant Fire Suppression System
L6000	PCL-600	Restaurant Fire Suppression System

Components and designs as listed in Technical Manual Kitchen Knight II, UL
Ex3470 Manual No. PN551274 dated October 1, 2001 (N01-61421) as listed under MEA
91-99-E Vol. II.

Recommendation - That the above pre-engineered fire suppression systems and
components, be accepted on condition that all uses, installations and
maintenance shall comply with all applicable New York City codes, rules,
regulations, etc., and in particular with RS 13-3 Section 7-2.2.4, RS 17-3, NFPA-
72 and the New York City Electrical Code, and on further condition that:

1. Installation and use shall comply with Underwriters Laboratories Inc.
requirements and limitations.
2. Installation shall conform to the manufacturer's pre-engineered,
installation, maintenance procedures and limitations.

All shipments and deliveries of such equipment shall be provided with a metal tag
suitably placed, certifying that the equipment shipped or delivered is equivalent to
that tested and accepted for use, as provided for in Section 27-131 of the Building
Code.

Final Acceptance October 29, 2003
Examined by [Signature]