



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 257-06-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name(s): System Sensor

Product: Fire Alarm Equipment.

Pertinent Code Section(s): RS 17-3, Subchapter 17.

Test(s): UL 268

Laboratory: Underwriters Laboratories Inc.

Test Report(s): S911, Project 86NK24359 issued April 30, 1987, revised April 19, 2006.

Description –

Model Number	Description
B401BH-2, B501BH-2, B501BHT-2	Smoke Detector Bases

Terms and Conditions: The above equipment is accepted provided that all uses, locations, and installations shall comply with Article 17, Reference Standard RS-17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance June 12, 2006

Examined by Donald Gattfried

(SD)