

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner  
MEA 28-00-M

Report of Material and Equipment Acceptance Division

Manufacturer – Simpson Dura-Vent, 902 Aldridge Road, Vacaville, CA 95688.

Trade Name(s) – Dura-Tech Chimney.

Product – Factory built chimney, residential type and for building heating appliance.

Pertinent Code Section(s) - 27-855.

Prescribed Test(s) -RS 15-8[A] (ANSI/UL 103).

Laboratory – Underwriters Laboratories Inc.

Test Report – UL File MH7399, dated September 21, 1993.

Description – Type HT, sizes 5,6,7 and 8 in. ID Chimneys and Chimney Parts. The chimney pipes may be made in lengths of 6, 12, 18, 24, 36 or 48 inches. The chimney consists of an inner stainless steel casing (flue gas conduit) with an outer stainless for CNL labeled chimneys, stainless steel or galvanized steel casing for USL labeled chimneys. The annular space between the inner and outer casings is insulated. The chimney is for single and multi-story buildings. The minimum installation clearance is 2 in. to enclosure walls and roof structure and as determined by specified factory furnished parts at floors, joists, roof and ceiling. Maximum chimney heights for the various support methods are as follows:

Ceiling support – 61 feet.

Roof support – 35 feet

Tee support – 60 feet

PRODUCT COVERED:

Chimney, residential type and building heating appliance, model DuraTech:SDT.

Recommendation - That the above described factory built chimneys, residential type or for building heating appliances, be accepted for use where allowed by the Building Code as Listed Factory Built chimneys intended for the venting of wood burning, liquid or gas fuel exhaust gases, at a temperature not exceeding that recommended by the manufacturer under continuous operating conditions. These chimneys shall not be used with Factory-Building fireplaces unless specifically referenced in the laboratory listing of the fireplace units. The chimney shall be installed in accordance with installation instructions provided by the manufacturer and in accordance with the Building Code for Listed Factory Built chimneys. All interior factory built chimneys shall be enclosed in accordance with the Code. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

1/25/2000

Examined by

S.M. Pinau