



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 286-07-E Vol. 2

Manufacturer: Honeywell International, Inc.
12 Clintonville Road
Northford, CT 06472

Trade Name(s): Notifier

Product: Control unit system and accessories

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17

Prescribed Test(s): 27-969 (UL864)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL S5526, Project 05NK06265, issued June 1, 2005
and revised December 11, 2007.

Description: Fire alarm control system and accessories.

The Notifier Noti-Fire-Gateway is a component for the ONYXWorks Facilities Monitoring Network Workstation. It is also available in a PC-based fiber version (**NFN-GW-PC-F**).

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated March 6, 2008, F.P. Index #0802041).

Terms and Conditions: The above-described Gateway product is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with all applicable provisions of the New York City Building Code, specifically with Subchapter 17 and with Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendations and UL standard.
2. The Interactive Firefighters' Display (FirstVision) shall be located in the lobby of the building on the entrance floor and shall be easily accessible to the responding firefighters/emergency personnel. In buildings where a fire command station is installed, FirstVision shall be at a location not greater than 10 (ten) feet from the fire command station.
3. ONYXWorks Workstation models shall be used primarily as annunciators for fire alarm system. All control functions of fire alarm shall be removed except for the ability to acknowledge alarm(s).
4. The above referenced Gateway shall be used to communicate with other panels and networks of fire alarm from building-to-building or for a campus-wide network communication. It shall not be used for fire alarm system communication within protected buildings. It may also be used as a means of ancillary communication to person(s) of interest, such as a building manager who wants to monitor and be informed of unusual conditions in the building's fire alarm system. It shall not be used for central station communication.
5. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131 (d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance March 20, 2008
Examined By [Signature]