

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

**MEA 29-04-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer – System Sensor, Unicorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, Illinois 60174.**

**Trade Name(s) – System Sensor, Unicorporated Division of Honeywell International.**

**Product – Fire Alarm Equipment.**

**Pertinent Code Section(s) –RS 17-3, RS 4-6 (886-89-BCR).**

**Test – UL 38.**

**Laboratory – Underwriters Laboratories, Inc.**

**Test Reports – UL File S739, Project 97NK17766, Volume 1, Section 6, issued July 28, 1997, revised January 19, 2001.**

**Description – Fire Alarm Equipment.**

<b>Model No.</b>	<b>Description</b>
<b>PSPI</b>	<b>Valve Supervisory Switch</b>

Pursuant to “Promulgation of the Rules relating to Materials and Equipment Application Procedures” dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated April 5, 2004, F.P. Index #0312041B.

**Recommendation-** That the above equipment be accepted on conditions that:

- 1. The above product shall be used only for supervision of non-rising stem gate valves that cannot be monitored by conventional supervisory switch in accordance with UL File S739 Vol. 1 Sec. 6.**

2. The owner or his authorized person shall be responsible to assure that the proper operation of this device is maintained. This device shall only be restored to normal when the valve is in normal condition.
3. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3.
4. UL and manufacturer's installation, maintenance procedures and limitations shall be complied with.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 27, 2004.  
Examined by Donald [Signature]