



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 297-01-E Vol.3

Manufacturer: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1610/

Trade Name(s): Silent Knight.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): 27-968 through 27-977, Reference Standard 17.

Prescribed Test(s): UL 864.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing Files: S2766, issued October 26, 2005, S2766, issued October 26, 2005, S2766, issued October 26, 2005, S3511, issued October 26, 2005.

Description – Fire Alarm Equipment.

Basically Listed Fire-Lite Models	Multiple Listed Silent Knight Models	Description
MS-2	SK-2	2 Zone Fire Alarm Control Panel
MS-4	SK-4	4 Zone Fire Alarm Control Panel
CAC-4	SK-CAC4	Converter Module
4XLM	SK-4XLM	Led Interface Module
4XTM	SK-4XTM	Transmitter Module
4XZM	SK-4XZM	Zone Relay Module
RZA-4XF	SK-RZA4	Remote Zone Annunciator
XRM-24	SK-XRM24	Transformer

Terms and Conditions: That the above units be accepted on condition that all uses, locations and installations shall comply with all applicable provisions of New York City Buildings Code, specifically Subchapter 17 and Reference Standards 17-3 through RS 17-5, inclusive as applicable including the NFPA as appropriate, the UL Listing, manufacturer's instructions, the Fire Department Directives, and with the Electrical Code of the City Of New York, and on further condition that:

1. When used as a central office control communicator or a transmitter, the installation and operation of the equipment and devices listed herein shall comply with 3-RCNY 17-01. It shall have the capability of transmitting separate and distinct signal to indicate manual pull station alarm. Automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
2. Prior to the installation of the pre-recorded automatic evacuation system, a specific approval for a specific installation must be obtained from the Fire Department.
3. The connection of security/burglar devices and equipment to a fire command station is prohibited. A sign must be posted to indicate the same.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 22, 2006
Examined by Donald [Signature]