

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 299-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1001.

Trade Name(s) - Fire-Lite.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - 27-977, RS 17-5, ANSI, NFPA 72.

Test(s) - RS 17-5, ANSI, NFPA 72, UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S624, Project 95NK26695, Vol. 20, dated March 14, 1996 and revised March 26, 1997, and S2424, Project 00NK4744, Vol. 10, dated June 5, 2000, and UL letter dated August 22, 2000.

Description - The MS-2410B is a ten zone Fire Alarm Control panel, which uses conventional input devices. It has 2 notification appliance circuits and three standard form-c relays (alarm, trouble, and supervisory). The RTB (Remote Trouble Buzzer) is a remote system trouble annunciator that provides annunciation via an LED and Piezo.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated December 6, 2000, F.P. Index No. 0008051 & 0009009.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3. The MS-2410B, IFA control panel and the remote trouble buzzer shall be used only with listed approved accessories with which the compatibility has been determined by a UL test report and on further condition that:

1. The connection of security/burglar devices and equipment to a fire control panel is prohibited. A sign shall be provided to indicate same.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 9, 2001

Examined By Mark J. Kelly