



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 299-02-E Vol. 2

Manufacturer: Fire-Lite Alarms, One Fire-Lite Place, Northford, CT 06472-1001

Trade Name(s): Honeywell Power Products

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 through 27-977 and Reference Standard RS 17

Prescribed Test(s): §27-969 (UL 864)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing File S6677 issued November 23, 2005 and revised August 7, 2007.

Description: Remote power supply/battery chargers, models **HPF-24S6** and **HPF-24S8**. The HPF-24S8 is capable of eight Amps and the HPF-24S6 is capable of six Amps of power. These chargers can be used with any MEA-approved fire alarm control panel.

Terms and Conditions: The above units are accepted on condition that;

1. All uses, configuration arrangements, functions, applications and installations shall comply with Article 17, Reference Standard RS 17 of the New York City Building Code, and the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance October 10, 2007.

Examined By Donald [Signature]