



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 303-07-E

Manufacturer: System Sensor, Unicorp. Div. of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17

Prescribed Test(s): Reference Standard RS 17-3 (UL 268A)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File S911, Projects 03NK06089 and 04CA30348, issued October 31, 2004 and revised October 11, 2006.

Description: An analog photoelectric-type smoke-automatic fire detector, **model ED-DPR**, designed for duct application.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated August 31, 2007, F.P. Index #0708037.

Terms and Conditions: The above equipment is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapters 13 & 17, and Reference Standards 17-3 & 17-5. Further, the installation of these detectors shall be in accordance with the manufacturer's recommendation and UL Standard 268A.

2. The above product shall be used only with approved/accepted control panel with which compatibility has been determined by the Engineer of Record or a UL test report.
3. Periodic maintenance and sensitivity tests shall be conducted in accordance with the regulations of the Fire Department and the manufacturer's recommendations.
4. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance September 17, 2007.

Examined By Donald [Signature]