

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 305-00-E

Report of Material and Equipment Acceptance Division
Manufacturer - Systems Sensor, A Division of Pittway, 3825 Ohio Avenue,
St. Charles, IL. 60174
Trade Name(s) - Honeywell.
Product - Fire Alarm Equipment.
Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).
Test(s) - UL 268A.
Laboratory - Underwriters Laboratories, Inc.
Test Report(s) - UL File S911, Project 00NK13414, issued July 17, 2000 and UL letter dated August 10, 2000.
Description - Honeywell's smoke detector as follows:

Model Number	Description
TC806D1011	Analog Duct Smoke Automatic Fire Detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated September 5, 2000, F.P. Index No. 0008074.

Recommendation - That the above equipment be accepted provided all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3. Further, the installation and spacing shall be in accordance with manufacturer's recommendation, NFPA 72 and UL standard. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 17, 2000
Examined By Mark Kelly