



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 306-87-E Vol. 2

**Manufacturer:** American Dryer Corporation  
88 Carrant Road  
Fall River, MA 02720

**Trade Name(s):** American Dryer Corporation (ADC)

**Product:** Commercial clothes dryers / Natural gas-fired  
Index #200-20 – Gas Dryer

**Pertinent Code Section(s):** 27-800, 27-807, RS 14-2 (ANSI Z223.1)

**Prescribed Test(s):** RS 14-6 (ANSI Z21.5)

**Laboratory:** CSA International

**Test Report(s):** CSA File 168704-1076155 dated June 5, 2008.

**Description:** Gas-fired automatic two-stacked clothes dryers with #30 drum capacity per pocket. Units are furnished with direct ignition systems comprising of steel-type burners, igniter with sensors, manual control valves, combination gas-pressure regulators, temperature controls and thermostats. Units, with model numbers, input heating ratings with pocket capacities are listed below:

Model No.	Heating Input Rating (Btu/hr)	Pocket Capacity
ADG-230(D)	144,000	72,000
ADG-235(ED)	144,000	72,000
ADG-235(D)	144,000	72,000
ADG-236(D)	160,000	80,000

**Note:** Units may be installed on combustible flooring. Minimum installed clearances from combustible construction shall be as follows: sides – 0 inches; top – 12 inches; rear – 12 inches.

**Terms and Conditions:** The above-described commercial clothes dryers are accepted under the following conditions:

1. Units shall be fired by natural gas only.
2. Provision for combustion air and ventilation air shall be made in accordance with Section 27-807 and other applicable New York City Building Code requirements.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Control Board before installation.
4. Units shall be installed and used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 24, 2008

Examined By Sun Deshpande