



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 308-06-E

**Manufacturer:** Bravo Systems International Inc., 7347 Atoll Avenue, North Hollywood, CA 91605

**Trade Name(s):** Bravo

**Product:** Pizza Ovens

**Pertinent Code Section(s):** 27-800, 27-826, RS 14-2 (ANSI Z223.1)

**Prescribed Test(s):** RS-14-6 (ANSI Z83.11)

**Laboratory:** Intertek Testing Services

**Test Report(s):** No. J98029644-001. Dated 04-28-98 Revised 10/23/03

**Description** – Gas fired ovens as listed below. Product covered:

Model No.	Mfgr's specified Nominal Gas Input BTUH
BRV-80G	98,000
BRV-100G	98,000
BRV-110G	98,000
BRV-120G	98,000
BRV-130G	98,000
BRV-140G	98,000
BRV-150G	98,000
BRV-160G	98,000
BRV-180G	98,000

**Note:** Clearances to combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

**Terms and Conditions:** The above commercial bakery ovens, are accepted, under the following conditions:

1. Units shall be fired by natural gas only.
2. Units shall be installed in accordance with manufacturer's instructions, National Fuel Gas Code, and the New York City Electrical Code requirements and the Energy Conservation Construction Code of New York State.
3. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS-13 requirements of the New York City Building Code and have a fire suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The Fire Suppression system exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.
4. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
5. Special precautions regarding exhaust fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
6. For grease removal, suitable MEA-accepted baffle type grease filters, shall be installed.
7. Gas line tubing and fitting connectors shall permit flexibility for operation, cleaning, and servicing, and shall be MEA- accepted for such use.
8. All gas line connections shall be made and equipment gas input settings shall be set by a licensed plumber.
9. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
10. All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
11. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Electrical Advisory Board before installation.

Final Acceptance 7/20/06

Examined by Shyam M. Prasad