



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 311-05-E

Manufacturer: CFM Majestic Inc., 475 Admiral Blvd., Mississauga ON L5T2N1 Canada

Trade Name(s): Vermont Castings, Majestic

Product: Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.88-1998).

Laboratory: CSA INTERNATIONAL

Test Report(s): Report No. 1622980, dated December 22, 2005.
Report No. 1646050 dated June 27, 2005.

Description – Direct vent and vented fireplace heaters designed for indoor installation for use as a decorative gas fireplace providing supplementary heat to the room, which installed. Unit comprises a forced draft system, combustion chamber and heat exchanger assembly, direct ignition system (consisting of pilot burner, and electrode, flame sensor and ignition module) or continuous pilot (consisting of safety shut-off device, thermocouple and piezo-electric ignition), combination gas pressure regulator and controls.

Model No.	Input Ratings BTUH
33LDV(T,R)	16,000
36LDV(T,R)	19,500
39LDV(T,R)	23,100
43LDV(T,R)	26,000
33XDV	21,500
36XDV	27,500
39XD	31,000

Terms and Conditions: That the above described gas fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electric equipment, apparatus, materials and devices shall be obtained from the Department before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 5/18/06

Examined by Shyam M. Jaiswal